

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION**

364 Knollcrest Drive, Suite 205 Redding, CA 96002

Phone (530) 224-4845 • Fax (530) 224-4857

[Central Valley Home Page](http://www.waterboards.ca.gov/centralvalley) (<http://www.waterboards.ca.gov/centralvalley>)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) CA0003981

ORDER R5-2020-XXXX

**WASTE DISCHARGE REQUIREMENTS
FOR THE SIERRA PACIFIC INDUSTRIES, BURNEY DIVISION SAWMILL, SHASTA COUNTY**

The following Discharger is subject to waste discharge requirements (WDR's) set forth in this Order:

Table 1. Discharger Information

Discharger:	Sierra Pacific Industries
Name of Facility:	Burney Division
Facility Street Address:	36336 Highway 299 East
Facility City, State, Zip:	Burney, CA 96013
Facility County:	Shasta County

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude (North)	Discharge Point Longitude (West)	Receiving Water
SW-005	Industrial storm water (see Attachment A for definition)	40° 52' 31.82"	121° 42' 17.95"	Canyon Creek
SW-006	Industrial storm water (see Attachment A for definition)	40° 52' 49.71"	121° 42' 18.01"	Tributary to Canyon Creek

Table 3. Administrative Information

This Order was Adopted on:	XX April 2020
This Order shall become effective on:	1 June 2020
This Order shall expire on:	31 May 2025
The Discharger shall file a Report of Waste Discharge (ROWD) as an application for reissuance of WDRs in accordance with title 23, California Code of Regulations, and an application for reissuance of a NPDES permit no later than: 1-year prior to Order expiration date	
The United States Environmental Protection Agency (U.S. EPA) and the California Regional Water Quality Control Board, Central Valley Region have classified this discharge as follows: Minor	

I, Patrick Pulupa, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of the Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on **05 May 2020**.

PATRICK PULUPA, Executive Officer

WASTE DISCHARGE REQUIREMENTS TABLE OF CONTENTS

I.	Facility Information	3
II.	Findings	3
III.	Discharge Prohibitions	4
IV.	Effluent Limitations and Discharge Specifications	5
	A. Effluent Limitations – Discharge Point SW-005 and SW-006	5
	1. Final Effluent Limitations – Discharge Points SW-005 and SW-006	5
	2. Interim Effluent Limitations – Not Applicable	6
	B. Land Discharge Specifications – Not Applicable	6
	C. Recycling Specifications – Not Applicable	6
V.	Receiving Water Limitations	6
	A. Surface Water Limitations	6
	B. Groundwater Limitations	8
VI.	Provisions	8
	A. Standard Provisions	8
	B. Monitoring and Reporting Program (MRP) Requirements	13
	C. Special Provisions	13
	1. Reopener Provisions	13
	2. Special Studies, Technical Reports and Additional Monitoring Requirements	14
	3. Best Management Practices and Pollution Prevention	16
	4. Construction, Operation and Maintenance Specifications	17
	5. Special Provisions for Publicly-Owned Treatment Works (POTWs) – Not Applicable	18
	6. Other Special Provisions	18
	7. Compliance Schedules – Not Applicable	19
VII.	Compliance Determination	19

TABLES

Table 1.	Discharger Information	1
Table 2.	Discharge Location	1
Table 3.	Administrative Information	1
Table 4.	Effluent Limitations	5
Table 5.	Storm Water Action Levels	14

ATTACHMENTS

Attachment A – Definitions	A-1
Attachment B – Map	B-1
Attachment C – Flow Schematic	C-1
Attachment D – Standard Provisions	D-1
Attachment E – Monitoring and Reporting Program	E-1
Attachment F – Fact Sheet	F-1
Attachment G – Summary Of compliance with receiving water objectives	G-1

I. FACILITY INFORMATION

Information describing the Sierra Pacific Industries, Burney Division (Facility) is summarized in Table 1 and in sections I and II of the Fact Sheet (Attachment F). Section I of the Fact Sheet also includes information regarding the Facility's permit application.

II. FINDINGS

The California Regional Water Quality Control Board, Central Valley Region (hereinafter Central Valley Water Board), finds:

- A. Legal Authorities.** This Order serves as waste discharge requirements (WDR's) pursuant to article 4, chapter 4, division 7 of the California Water Code (commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. EPA and chapter 5.5, division 7 of the Water Code (commencing with section 13370). It shall serve as a National Pollutant Discharge Elimination System (NPDES) permit authorizing the Discharger to discharge into waters of the United States at the discharge location described in Table 2 subject to the WDR's in this Order.
- B. Background and Rationale for Requirements.** The Central Valley Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for the requirements in this Order, is hereby incorporated into and constitutes Findings for this Order. Attachments A through E and G are also incorporated into this Order.
- C. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections V.B, VI.C.4, and VI.C.6 are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations. Subsections IV.B, IV.C, and VI.C.5 are not applicable.
- D. Monitoring and Reporting.** 40 C.F.R. section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Central Valley Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. The Monitoring and Reporting Program is provided in Attachment E.

The technical and monitoring reports in this Order are required in accordance with Water Code section 13267, which states the following in subsection (b)(1), "In conducting an investigation specified in subdivision (a), the regional board may require that any person who has discharged, discharges, or is suspected of having discharged discharging, or who proposes to discharge waste within its region, or any citizen or domiciliary, or political agency or entity of this state who has discharged,

discharges, or is suspected of having discharged or discharging, or who proposes to discharge, waste outside of its region could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports and shall identify the evidence that supports requiring that person to provide the reports.”

The Discharger owns and operates the Facility subject to this Order. The monitoring reports required by this Order are necessary to determine compliance with this Order. The need for the monitoring reports is discussed in the Fact Sheet.

- E. Notification of Interested Persons.** The Central Valley Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe WDR’s for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of the notification are provided in the Fact Sheet.
- F. Consideration of Public Comment.** The Central Valley Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

THEREFORE, IT IS HEREBY ORDERED that Order R5-2015-0071 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order. This action in no way prevents the Central Valley Water Board from taking enforcement action for violations of the previous Order.

III. DISCHARGE PROHIBITIONS

- A.** Discharge of wastewater from the Facility, as the Facility is specifically described in the Fact Sheet in section II.B, in a manner different from that described in this Order is prohibited.
- B.** The by-pass or overflow of wastes to surface waters is prohibited, except as allowed by Federal Standard Provisions I.G. and I.H. (Attachment D).
- C.** Neither the discharge nor its treatment shall create a nuisance as defined in section 13050 of the Water Code.
- D.** The discharge of recycle water from log yard sprinkling, commingled recycle and storm water (i.e., “first flush”), cooling tower blowdown, boiler blowdown, demineralizer regeneration wastewater, or other waste of recognizable sawmill or cogeneration origin to surface waters is prohibited.

- E. The discharge of storm water leachate from wood fuel stockpiles to surface waters or surface water drainage courses is prohibited. Best management practices (BMP's) must be implemented to prevent such discharge.
- F. The discharge of ash, bark, sawdust, wood, or any waste recognized as originating from cogeneration operations to surface waters or surface water drainage courses is prohibited.
- G. Discharge of wastewater from the Facility retention ponds, evaporation ponds, and substation pond off-site is prohibited except to a suitable treatment plant or for reclamation purposes specifically approved by the Executive Officer.
- H. The discharge of debris (as defined in Attachment A) recognized as originating from the Facility to surface waters or surface water drainage courses is prohibited.
- I. The discharge of process wastewater from barking, sawmill, and planing operations, as defined in 40 C.F.R. part 429, is prohibited.
- J. Discharge of waste classified as 'hazardous,' as defined in the California Code of Regulations (CCR), Title 22, section 66261.1 et seq., including water treatment chemicals, solvents, or petroleum products (e.g., oil, grease, gasoline, and diesel), is prohibited.
- K. Discharge of waste classified as "hazardous" as defined in CCR, Title 23, section 2521(a), or "designated" (other than as specifically allowed in this Order), as defined in section 13173 of the Water Code, to the ponds is prohibited.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point SW-005 and SW-006

1. Final Effluent Limitations – Discharge Points SW-005 and SW-006

The Discharger shall maintain compliance with the following effluent limitations at Discharge Point **SW-005 and SW-006**. Unless otherwise specified compliance shall be measured at Monitoring Location **EFF-001 and EFF-002**, as described in the Monitoring and Reporting Program, Attachment E:

- a. The Discharger shall maintain compliance with the effluent limitations specified in Table 4:

Table 4. Effluent Limitations

Parameters	Units	Average Monthly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
pH	standard units	--	--	6.0	9.0

- b. **Acute Whole Effluent Toxicity.** Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

- i. 70%, minimum for any one bioassay; and
- ii. 90%, median for any three consecutive bioassays.

2. Interim Effluent Limitations – Not Applicable

B. Land Discharge Specifications – Not Applicable

C. Recycling Specifications – Not Applicable

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

The discharge shall not cause the following in Canyon Creek:

1. **Bacteria.** The fecal coliform concentration, based on a minimum of not less than five samples for any 30-day period, to exceed a geometric mean of 200 MPN/100 mL, nor more than 10 percent of the total number of fecal coliform samples taken during any 30-day period to exceed 400 MPN/100 mL.
2. **Biostimulatory Substances.** Water to contain biostimulatory substances which promote aquatic growths in concentrations that cause nuisance or adversely affect beneficial uses.
3. **Chemical Constituents.** Chemical constituents to be present in concentrations that adversely affect beneficial uses.
4. **Color.** Discoloration that causes nuisance or adversely affects beneficial uses.
5. **Dissolved Oxygen:**
 - a. The monthly median of the mean daily dissolved oxygen concentration to fall below 85 percent of saturation in the main water mass;
 - b. The 95-percentile dissolved oxygen concentration to fall below 75 percent of saturation; nor
 - c. The dissolved oxygen concentration to be reduced below 7.0 mg/L at any time.
6. **Floating Material.** Floating material to be present in amounts that cause nuisance or adversely affect beneficial uses.
7. **Oil and Grease.** Oils, greases, waxes, or other materials to be present in concentrations that cause nuisance, result in a visible film or coating on the surface of the water or on objects in the water, or otherwise adversely affect beneficial uses.
8. **pH.** The pH to be depressed below 6.5 nor raised above 8.5.

9. **Pesticides:**

- a. Pesticides to be present, individually or in combination, in concentrations that adversely affect beneficial uses;
- b. Pesticides to be present in bottom sediments or aquatic life in concentrations that adversely affect beneficial uses;
- c. Total identifiable persistent chlorinated hydrocarbon pesticides to be present in the water column at concentrations detectable within the accuracy of analytical methods approved by U.S. EPA or the Executive Officer;
- d. Pesticide concentrations to exceed those allowable by applicable antidegradation policies (see State Water Board Resolution No. 68-16 and 40 CFR section 131.12.);
- e. Pesticide concentrations to exceed the lowest levels technically and economically achievable;
- f. Pesticides to be present in concentration in excess of the maximum contaminant levels (MCL's) set forth in CCR, Title 22, division 4, chapter 15; nor
- g. Thiobencarb to be present in excess of 1.0 µg/L.

10. **Radioactivity:**

- a. Radionuclides to be present in concentrations that are harmful to human, plant, animal, or aquatic life nor that result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life.
- b. Radionuclides to be present in excess of the MCL's specified in Table 64442 of section 64442 and Table 64443 of section 64443 of Title 22 of the California Code of Regulations.

11. **Suspended Sediments.** The suspended sediment load and suspended sediment discharge rate of surface waters to be altered in such a manner as to cause nuisance or adversely affect beneficial uses.

12. **Settleable Substances.** Substances to be present in concentrations that result in the deposition of material that causes nuisance or adversely affects beneficial uses.

13. **Suspended Material.** Suspended material to be present in concentrations that cause nuisance or adversely affect beneficial uses.

14. **Taste and Odors.** Taste- or odor-producing substances to be present in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses.
15. **Temperature.** The natural temperature to be increased by more than 5° Fahrenheit. Compliance to be determined based on the difference in temperature at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004.
16. **Toxicity.** Toxic substances to be present, individually or in combination, in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life.
17. **Turbidity.**
 - a. Shall not exceed 2 Nephelometric Turbidity Units (NTU) where natural turbidity is less than 1 NTU;
 - b. Shall not increase more than 1 NTU where natural turbidity is between 1 and 5 NTUs;
 - c. Shall not increase more than 20 percent where natural turbidity is between 5 and 50 NTUs;
 - d. Shall not increase more than 10 NTU where natural turbidity is between 50 and 100 NTUs; nor
 - e. Shall not increase more than 10 percent where natural turbidity is greater than 100 NTUs.

B. Groundwater Limitations

Release of waste constituents from any storage, treatment, or disposal component associated with the facility, in combination with other sources, shall not cause the underlying groundwater to contain waste constituents greater than background quality or water quality objectives, whichever is greater.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D.
2. The Discharger shall comply with the following provisions. In the event that there is any conflict, duplication, or overlap between provisions specified by this Order, the more stringent provision shall apply:

- a. If the Discharger's wastewater treatment plant is publicly owned or subject to regulation by California Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to Title 23, CCR, division 3, chapter 26.
- b. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
 - i. violation of any term or condition contained in this Order;
 - ii. obtaining this Order by misrepresentation or by failing to disclose fully all relevant facts;
 - iii. a change in any condition that requires either a temporary or permanent reduction or elimination of the authorized discharge; and
 - iv. a material change in the character, location, or volume of discharge.

The causes for modification include:

- i. New regulations. New regulations have been promulgated under section 405(d) of the CWA, or the standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued.
- ii. Land application plans. When required by a permit condition to incorporate a land application plan for beneficial reuse of sewage sludge, to revise an existing land application plan, or to add a land application plan.
- iii. Change in sludge use or disposal practice. Under 40 CFR section 122.62(a)(1), a change in the Discharger's sludge use or disposal practice is a cause for modification of the permit. It is cause for revocation and reissuance if the Discharger requests or agrees.

The Central Valley Water Board may review and revise this Order at any time upon application of any affected person or the Central Valley Water Board's own motion.

- c. If a toxic effluent standard or prohibition (including any scheduled compliance specified in such effluent standard or prohibition) is established under section 307(a) of the CWA, or amendments thereto, for a toxic pollutant that is present in the discharge authorized herein, and such standard or prohibition is more stringent than any limitation upon such pollutant in this Order, the Central Valley Water Board will revise or modify this Order in accordance with such toxic effluent standard or prohibition.

The Discharger shall comply with effluent standards and prohibitions within the time provided in the regulations that establish those standards or prohibitions, even if this Order has not yet been modified.

- d. This Order shall be modified, or alternately revoked and reissued, to comply with any applicable effluent standard or limitation issued or approved under sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the CWA, if the effluent standard or limitation so issued or approved:
 - i. Contains different conditions or is otherwise more stringent than any effluent limitation in the Order; or
 - ii. Controls any pollutant limited in the Order.

The Order, as modified or reissued under this paragraph, shall also contain any other requirements of the CWA then applicable.

- e. The provisions of this Order are severable. If any provision of this Order is found invalid, the remainder of this Order shall not be affected.
- f. The Discharger shall take all reasonable steps to minimize any adverse effects to waters of the State or users of those waters resulting from any discharge or sludge use or disposal in violation of this Order. Reasonable steps shall include such accelerated or additional monitoring as necessary to determine the nature and impact of the non-complying discharge or sludge use or disposal.
- g. The Discharger shall ensure compliance with any existing or future pretreatment standard promulgated by U.S. EPA under section 307 of the CWA, or amendment thereto, for any discharge to the municipal system.
- h. A copy of this Order shall be maintained at the discharge facility and be available at all times to operating personnel. Key operating personnel shall be familiar with its content.
- i. Safeguard to electric power failure:
 - i. The Discharger shall provide safeguards to assure that, should there be reduction, loss, or failure of electric power, the discharge shall comply with the terms and conditions of this Order.
 - ii. Upon written request by the Central Valley Water Board, the Discharger shall submit a written description of safeguards. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means. A description of the safeguards provided shall include an analysis of the frequency, duration, and impact of power failures

experienced over the past 5 years on effluent quality and on the capability of the Discharger to comply with the terms and conditions of the Order. The adequacy of the safeguards is subject to the approval of the Central Valley Water Board.

- iii. Should the treatment works not include safeguards against reduction, loss, or failure of electric power, or should the Central Valley Water Board not approve the existing safeguards, the Discharger shall, within 90 days of having been advised in writing by the Central Valley Water Board that the existing safeguards are inadequate, provide to the Central Valley Water Board and U.S. EPA a schedule of compliance for providing safeguards such that in the event of reduction, loss, or failure of electric power, the Discharger shall comply with the terms and conditions of this Order. The schedule of compliance shall, upon approval of the Central Valley Water Board, become a condition of this Order.
- j. The Discharger, upon written request of the Central Valley Water Board, shall file with the Board a technical report on its preventive (failsafe) and contingency (cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. This report may be combined with that required under the Central Valley Water Board Standard Provision contained in section VI.A.2.i of this Order.

The technical report shall:

- i. Identify the possible sources of spills, leaks, untreated waste by-pass, and contaminated drainage. Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.
- ii. Evaluate the effectiveness of present facilities and procedures and state when they became operational.
- iii. Predict the effectiveness of the proposed facilities and procedures and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

The Central Valley Water Board, after review of the technical report, may establish conditions which it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions shall be incorporated as part of this Order, upon notice to the Discharger.

- k. The Discharger shall submit technical reports as directed by the Executive Officer. All technical reports required herein that involve planning, investigation, evaluation, or design, or other work requiring interpretation and proper application of engineering or geologic sciences, shall be prepared by or under the direction of persons registered to practice in

California pursuant to California Business and Professions Code, sections 6735, 7835, and 7835.1. To demonstrate compliance with Title 16, CCR, sections 415 and 3065, all technical reports must contain a statement of the qualifications of the responsible registered professional(s). As required by these laws, completed technical reports must bear the signature(s) and seal(s) of the registered professional(s) in a manner such that all work can be clearly attributed to the professional responsible for the work.

- I. The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.
- m. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Central Valley Water Board.

To assume operation under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the state of incorporation if a corporation, address and telephone number of the persons responsible for contact with the Central Valley Water Board and a statement. The statement shall comply with the signatory and certification requirements in the federal Standard Provisions (Attachment D, section V.B) and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the Water Code. Transfer shall be approved or disapproved in writing by the Executive Officer.

- n. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
- o. In the event the Discharger does not comply or will be unable to comply for any reason, with any prohibition, effluent limitation, or receiving water limitation of this Order, the Discharger shall notify the Central Valley Water Board by telephone (916) 464-3291 within 24 hours of having knowledge of such noncompliance, and shall confirm this notification in writing within five days, unless the Central Valley Water Board waives confirmation. The written notification shall state the nature, time, duration, and cause of noncompliance, and shall describe the measures being taken to remedy

the current noncompliance and prevent recurrence including, where applicable, a schedule of implementation. Other noncompliance requires written notification as above at the time of the normal monitoring report.

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E.

C. Special Provisions

1. Reopener Provisions

- a. Conditions that necessitate a major modification of a permit are described in 40 CFR section 122.62, including, but not limited to:
 - i. If new or amended applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, this permit may be reopened and modified in accordance with the new or amended standards.
 - ii. When new information, that was not available at the time of permit issuance, would have justified different permit conditions at the time of issuance.
- b. This Order may be reopened for modification, or revocation and reissuance, as a result of the detection of a reportable priority pollutant generated by special conditions included in this Order. These special conditions may be, but are not limited to, fish tissue sampling, whole effluent toxicity, monitoring requirements on internal waste stream(s), and monitoring for surrogate parameters. Additional requirements may be included in this Order as a result of the special condition monitoring data.
- c. **Water Effects Ratios (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating criteria for applicable inorganic constituents. In addition, default dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
- d. **Drinking Water Policy.** On 26 July 2013 the Central Valley Water Board adopted Resolution No. R5-2013-0098 amending the Basin Plan and establishing a Drinking Water Policy. The State Water Board approved the Drinking Water Policy on 3 December 2013. This Order may be reopened to incorporate monitoring of drinking water constituents to implement the Drinking Water Policy.

- e. **Central Valley Salinity Alternatives for Long-Term Sustainability (CV-SALTS).** On 31 May 2018, as part of the CV-SALTS initiative, the Central Valley Water Board Approved Basin Plan Amendments to incorporate new strategies for addressing ongoing salt and nitrate accumulation in the Central Valley. On 16 October 2019 the State Water Board approved the Amendments. If approved by the Office of Administrative Law and U.S. EPA, the Amendments would impose certain new requirements on salt and nitrate discharges. More information regarding these Amendments can be found on the [Central Valley Salinity Alternatives for Long-Term Sustainability \(CV-SALTS\) web page](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/):
(https://www.waterboards.ca.gov/centralvalley/water_issues/salinity/)

If the Amendments ultimately go into effect, this Order may be amended or modified to incorporate any newly-applicable requirements.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. **Storm Water Action Levels and Best Management Practice (BMP) Improvement Evaluation.** If the discharge from Discharge Point SW-005 or SW-006 exceeds any industrial storm water action level in Table 5 or any receiving water limitation in section V.A, the Discharger must conduct a BMP Improvement Evaluation and implement, if necessary, BMP improvements to reduce the industrial storm water pollutant concentrations below the action level and/or eliminate the receiving water limit violation. The BMP Improvement Evaluation and proposed BMP improvements must be submitted to the Central Valley Water Board within 60 days of the storm water action level exceedance or receiving water limit violation date. The BMP improvement(s) must be implemented as soon as practicable thereafter. The Facility Industrial Storm Water Pollution Prevention Plan (SWPPP) shall be updated in response to any implemented BMP improvements, as appropriate.

This Order includes the following storm water action levels:

Table 5. Storm Water Action Levels

Parameters	Units	Instantaneous Maximum Action Level	Annual Action Level
Chemical Oxygen Demand (COD)	mg/L	--	120
Iron, Total Recoverable	ug/L	--	1,000
Oil and Grease	mg/l	--	15
Total Suspended Solids	mg/L	400	100
Tannins and Lignins	mg/L	--	30

- i. Compliance with the Storm Water Action Levels will be evaluated as an annual average.
 - ii. The storm water action levels in Table 5 are not effluent limitations on the industrial storm water discharge. An exceedance of an action level does not constitute a violation of this Order.
- b. **Facility Water Balance Evaluation Work Plan.** The Discharger shall prepare and submit a work plan for Central Valley Water Board staff approval to study the water balance for the log deck area, land application area, fire pond drainage area, retention pond, and evaporation ponds to determine if there is adequate first flush storage capacity. Submittal of the work plan shall be in accordance with the time schedule in the Technical Reports Table E-12.
- c. **Facility Water Balance Evaluation Study.** The Discharger shall prepare and submit a study of the water balance for the log deck area, land application area, fire pond drainage area, retention pond, and evaporation ponds in accordance with the approved work plan to determine if there is adequate first flush storage capacity. Submittal of the final report shall be in accordance with the time schedule in the Technical Reports Table E-12.
- d. **Downgradient Monitoring Wells Evaluation.** Based on the groundwater monitoring results and a technical report from the previous permit term, the concentrations of certain constituents in downgradient wells MW-3 and MW-4 are statistically higher than background concentrations. The Discharger asserts downgradient concentrations of certain constituents are not elevated due to Facility discharges to groundwater, rather because the downgradient monitoring wells are in the area of a pond historically used for holding logs. Therefore, the Discharger shall evaluate whether new downgradient wells are necessary to correctly characterize downgradient groundwater quality in order to determine if degradation is occurring. The Discharger shall submit a Downgradient Monitoring Wells Evaluation Report and Monitoring Well Installation Workplan (if applicable) no later than 1 year after the effective date of this Order.

In accordance with California Business and Professions Code Sections 6735, 7835, and 7835.1, engineering and geologic evaluations and judgments shall be performed by or under the direction of registered professionals competent and proficient in the fields pertinent to the required activities. The technical report shall be prepared by or under the direction of appropriately qualified professional(s) and shall bear the professional's signature and stamp.

- e. **Antidegradation Re-evaluation**

As part of an iterative evaluation of compliance with State Water Board Resolution 68-16, the Statement of Policy with Respect to Maintaining

High Quality of Waters in California (State Anti-Degradation Policy), the Discharger shall submit an Antidegradation Reevaluation with its Report of Waste Discharge. The Antidegradation Reevaluation must use information obtained from the Downgradient Monitoring Wells Evaluation Report required in section VI.C.2.d, in addition to results of the land discharge and groundwater monitoring, to confirm that any groundwater degradation that has occurred as a result of Facility operations has not resulted in any exceedances of applicable groundwater water quality objectives or in any impacts to beneficial uses.

If the data indicate that exceedances of applicable groundwater water quality objectives or impacts to beneficial uses have occurred, the Discharger shall include a work plan (with an implementation schedule) to implement additional treatment or control measures to further limit any impacts from the ponds. Determination of background groundwater quality for use in the analysis shall be made using the methods described in Title 27 California Code of Regulations Section 20415(e)(10) or other method approved by the Executive Officer.

3. Best Management Practices and Pollution Prevention

a. Storm Water Pollution Prevention Plan (SWPPP)

i. This Order requires the Discharger to continue to implement a site-specific SWPPP for the Facility. An updated SWPPP that addresses the necessary BMP's to ensure compliance with the industrial storm water action levels specified in Table 5 shall be submitted to the Central Valley Water Board by 1 October 2020. The SWPPP must include the information needed to demonstrate compliance with all requirements of this Order and shall contain at a minimum, the following elements:

- (a) Facility name and contact information;
- (b) Site map;
- (c) List of significant materials;
- (d) Description of potential pollution sources;
- (e) Assessment of potential pollutant sources;
- (f) Minimum BMP's;
- (g) Advanced BMP's, if applicable;
- (h) Monitoring Implementation Plan; and
- (i) Date that SWPPP was initially prepared and the date of each SWPPP amendment, if applicable.

- ii. **BMP Summary Table.** The Discharger shall prepare a table, to be included in the SWPPP, summarizing each identified area of industrial activity, the associated industrial pollutant sources, the industrial pollutants, and the BMP's being implemented.
- iii. **SWPPP Revisions.** The Discharger shall amend the SWPPP whenever there is a change in construction, site operation, or maintenance, which may affect the discharge of significant quantities of pollutants to surface water or groundwater. The SWPPP must also be amended if there are violations of this permit, or the Discharger has not achieved the general objectives of controlling pollutants in the storm water discharges. If the SWPPP has been significantly revised, the revised SWPPP shall be submitted to the Central Valley Water Board for review.
- iv. **Salinity Evaluation and Minimization.** The SWPPP amendment shall include a salinity evaluation and minimization plan to identify and address sources of salinity discharged from the Facility.
- v. A copy of the SWPPP shall be maintained at the facility.
- b. **Facility-Specific Best Management Practice (BMP) – First Flush Collection.** Each year, after cessation of log yard sprinkling, the Discharger shall collect the first 2 inches of rainfall from the log deck area plus any process water remaining in the Log Yard Pond when collection of the flush commences (i.e., "first flush" or "comingled log deck sprinkle water and storm water"). The first flush shall be conveyed to the Retention Pond and evaporation ponds. The "first flush" shall not reach surface water. The "first flush" must be collected and conveyed to the Retention Pond and evaporation ponds after any subsequent sprinkling of the logs prior to storm water discharge to surface water. This Facility-specific BMP may be modified by approval of the Executive Officer.

4. Construction, Operation and Maintenance Specifications

- a. Facility Retention Ponds, Fire Pond, Evaporation Ponds, and Substation Pond Operating Requirements
 - i. The treatment facilities shall be designed, constructed, operated, and maintained to prevent inundation or washout due to floods with a 100-year return frequency.
 - ii. Public contact with wastewater shall be precluded through such means as fences, signs, and other acceptable alternatives.
 - iii. All ponds and open containment structures shall be managed to prevent breeding of mosquitoes. The Discharger has a memorandum

of understanding with Shasta County Mosquito Vector and Control to maintain best management practices to control vector populations.

- iv. Freeboard shall never be less than 2 feet (measured vertically to the lowest point of overflow) except if lesser freeboard does not threaten the integrity of the pond, no overflow of the pond occurs, and lesser freeboard is due to direct precipitation or storm water runoff occurring as a result of annual precipitation with greater than 100-year recurrence interval, or a storm event with an intensity greater than a 25-year, 24-hour storm event.
- v. The Log Deck Recycle Pond, Retention Pond, and Evaporation Ponds, in combination shall have enough capacity to store the runoff from the log deck resulting from the cumulative total of 2 inches of rainfall measured at the Facility according to section IX.A of the MRP, Attachment E. The cumulative total of 2 inches of rainfall shall commence on the date the sprinkling of the log deck ceases for the wet season.
- vi. Objectionable odors originating at the Facility shall not be perceivable beyond the limits of the pond areas (or property owned by the Discharger).
- vii. As a means of discerning compliance with section VI.C.4.a.v, above, the dissolved oxygen content in the upper zone (1 foot) of wastewater in ponds shall not be less than 1.0 mg/L. This requirement does not apply when the pond contains less than 1.0 foot of water at its shallowest point.
- viii. Ponds shall not have a pH less than 6.0 or greater than 9.0.
- ix. Freeboard shall never be less than 2 feet (measured vertically to the lowest point of overflow) except if lesser freeboard does not threaten the integrity of the pond, no overflow of the pond occurs, and lesser freeboard is due to direct precipitation or storm water runoff occurring as a result of annual precipitation with greater than a 100-year recurrence interval, or a storm event with an intensity greater than a 25-year, 24-hour storm event.
- x. The discharge shall not cause degradation of any water supply.
- xi. Management of wood fuel stockpiles and ash stockpiles shall not adversely affect groundwater quality.

5. Special Provisions for Publicly-Owned Treatment Works (POTWs) – Not Applicable

6. Other Special Provisions

- a. Sludge, Wood Waste, and/or Ash Management
 - i. Collected screenings, sludge, and other solids removed from liquid wastes shall be disposed of in a manner approved by the Executive Officer and consistent with Consolidated Regulations for Treatment, Storage, Processing, or Disposal of Solid Waste, as set forth in Title 27, California Code of Regulations (CCR), Division 2, Subdivision 1, Section 20005, et seq.
 - ii. **Ash Management Plan.** The Discharger shall continue to implement their ash management plan and submit annual reports to the Central Valley Water Board. The annual reports shall describe at a minimum:
 - (a) Sources and amount of ash generated annually.
 - (b) Locations(s) of on-site storage and description of containment area.
 - (c) Plans for ultimate disposal. For landfill disposal, include the present classification of the landfill and the name and location of the landfill.
 - iii. Any proposed change in sludge or ash use or disposal practice shall be reported to the Executive Officer at least 30 days in advance of the change.
 - iv. Non-hazardous ash removed from the facility shall be:
 - (a) Beneficially reused, such as for soil amendment; or
 - (b) Disposed in a dedicated unit consistent with Title 27, Section 20200(b); or
 - (c) Disposed in a Class III landfill consistent with Title 27, Section 20220(d).
- Any other use shall require approval by the Executive Officer.
- v. This Order does not authorize storage, transportation, or disposal of ash or other wastes characterized as hazardous wastes. Appropriate separate regulatory coverage must be secured for such activities.

7. Compliance Schedules – Not Applicable

VII. COMPLIANCE DETERMINATION

- A. **Industrial Storm Water Action Levels (Section VI.C.2.c, Table 5).** The storm water action levels in Table 5 are not effluent limitations on the industrial storm water discharge. An exceedance of an action level does not constitute a violation of this Order. The action levels are the pollutant concentrations above which the Central Valley Water Board has determined represent a level of concern and require further

evaluation of the Discharger's SWPPP as it relates to controlling the discharge of the subject pollutant from the Facility. Exceedance of an action level requires the Discharger to conduct a BMP Improvement Evaluation in accordance with section VI.C.2.a.

- B. Dissolved Oxygen Receiving Water Limitation** (Section V.A.5.a-c). Weekly receiving water monitoring during periods of discharge is required in the MRP (Attachment E) and is sufficient to evaluate the impacts of the discharge and compliance with this Order. Weekly receiving water monitoring data, measured at monitoring locations RSW-001, RSW-002, RSW-003, and RSW-004 will be used to determine compliance with part "c" of the dissolved oxygen receiving water limitation to ensure the discharge does not cause the dissolved oxygen concentrations in Canyon Creek to be reduced below 7.0 mg/L at any time. However, should more frequent dissolved oxygen and temperature receiving water monitoring be conducted, Central Valley Water Board staff may evaluate compliance with parts "a" and "b".

ATTACHMENT A – DEFINITIONS

Annual

Calendar year, January through December

Arithmetic Mean (μ)

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n$$

where: Σx is the sum of the measured ambient water concentrations, and n is the number of samples.

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best Management Practices (BMP's)

Those control measures taken to mitigate changes to both quantity and quality of runoff caused through changes to land use. Specifically, those measures that are required to reduce or prevent pollutants in industrial storm water discharges in compliance with BAT/BCT.

Bioaccumulative

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic

Pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV)

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Debris

Debris is defined as woody material such as bark, twigs, branches, heartwood or sapwood that will not pass through a 2.54 cm (1.0 in) diameter round opening and is present in the discharge from a wet storage facility.

Detected, but Not Quantified (DNQ)

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL. Sample results reported as DNQ are estimated concentrations.

Dilution Credit

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA)

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Endpoint

An effect that is measured in a toxicity study. Endpoints in toxicity tests may include, but are not limited to survival, reproduction, and growth.

Estimated Chemical Concentration

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters

All surface waters of the state that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL)

MDL is the minimum measured concentration of a substance that can be reported with 99 percent confidence that the measured concentration is distinguishable from method blank results, as defined in 40 C.F.R. Part 136, Attachment B.

Minimum Level (ML)

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

No-Observed-Effect-Concentration (NOEC)

The highest concentration of toxicant to which organisms are exposed in a full life-cycle or partial life-cycle (short-term) test, that causes no observable adverse effects on the test organisms (i.e., the highest concentration of toxicant in which the values for the observed responses are not statistically significantly different from the controls).

Not Detected (ND)

Sample results which are less than the laboratory's MDL.

Ocean Waters

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Percent Effect

The percent effect at the instream waste concentration (IWC) shall be calculated using untransformed data and the following equation:

$$\text{Percent Effect of the Sample} = \frac{\text{Mean Control Response} - \text{Mean Sample Response}}{\text{Mean Control Response}} \cdot 100$$

Persistent Pollutants

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP)

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Central Valley Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product

reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State Water Resources Control Board (State Water Board) or Central Valley Water Board.

Process Wastewater

Process wastewater shall include log yard sprinkling water, cogen blowdown, and “first flush” storm water from the Drainage Area NPDES 2-1 through Drainage Area NPDES 2-4.

Attachment C includes a site plan that identifies Drainage Area NPDES 2-1 through Drainage Area NPDES 2-4.

Satellite Collection System

The portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) in a Central Valley Water Board Basin Plan.

Standard Deviation (σ)

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum [(x - \mu)^2] / (n - 1))^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Storm Water

Storm water runoff from the site originates from a 25-acre log yard area, fuel building, rolling stock shop, sawmill, oil shed, fuel house, cogeneration plant, and cooling tower (Industrial Storm Water) and the remaining areas of the Facility (General Industrial Storm Water). The site plan in Attachment C delineates these areas and is defined as follows:

First Flush Storm Water. Storm water in Drainage Area NPDES 2-1 through NPDES 2-4 is regulated by this Order as Industrial Storm Water. “First Flush” storm water is defined as Industrial Storm Water from the first 2 inches of rainfall in these drainage areas commencing when log yard sprinkling with pond water has ceased plus the volume of sprinkling water remaining in the pond prior to rainfall. The “first flush” collection may occur more than once in a wet season if the Discharger intermittently sprinkles logs with pond water during the wet season.

Industrial Storm Water. Industrial storm water in Drainage Areas NPDES 1-1 through NPDES 1-3, Drainage Areas NPDES 2-1 through NPDES 2-4, and the Land Application Area is regulated by this Order. Industrial Storm Water is defined as storm water runoff from these drainage areas, which may contain non-contact saw cooling water, kiln condensate, direct contact with decked logs, direct contact with wood byproducts, and sediment, after the “first flush” storm water is collected. This Facility falls under the SIC code 2421 for Sawmills and Planing Mills, General, for which coverage is authorized under State Water Resources Control Board (State Water Board) Water Quality Order No. 2014-0057-DWQ, NPDES General Permit No. CAS000001. The activities conducted in these drainage areas is consistent with the SIC Code and the authorized coverage under the IGP, however this individual permit was required until the Discharger could eliminate pollutants in the discharge and comply with the numeric action levels in the General Permit.

General Industrial Storm Water. This Order does not regulate discharges of general industrial storm water from Drainage Area 1 through Drainage Area 5. All storm water runoff from Drainage Area 1 through Drainage Area 5 is directed to discharge to Canyon Creek via four outfalls (i.e., SW-1, SW-2, SW-3, and SW-4) under the State Water Resources Control Board (State Water Board) Water Quality Order No. 2014-0057-DWQ, NPDES General Permit No. CAS000001.

FACILITY LOCATION

REMEDY ENGINEERING, INC.
2510 OLD EUREKA WAY
REDDING, CA 96001
PHONE: (530) 241-7655


REVIEWED BY: NJB
DATE: 12/5/19

DRAWN BY: MRW
CLIENT: SPI BSW

FACILITY LOCATION MAP
BURNLEY DIVISION SAWMILL
SIERRA PACIFIC INDUSTRIES
BURNLEY, CALIFORNIA

FIGURE 1

ATTACHMENT C – FLOW SCHEMATIC



ATTACHMENT D – STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply:

1. The Discharger must comply with all of the terms, requirements, and conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action; permit termination, revocation and reissuance, or modification; denial of a permit renewal application; or a combination thereof. (40 C.F.R. section 122.41(a); Wat. Code, sections 13261, 13263, 13265, 13268, 13000, 13001, 13304, 13350, 13385.)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. section 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. section 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. section 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes having adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. section 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. section 122.41(g).)

2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. section 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Central Valley Water Board, State Water Board, U.S. EPA, and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (33 U.S.C. section 1318(a)(4)(B); 40 C.F.R. section 122.41(i); Wat. Code, section 13267, 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (33 U.S.C section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(1); Wat. Code, sections 13267, 13383);
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (33 U.S.C. section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(2); Wat. Code, sections 13267, 13383);
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (33 U.S.C section 1318(a)(4)(B)(ii); 40 C.F.R. section 122.41(i)(3); Wat. Code, section 13267, 13383); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (33 U.S.C section 1318(a)(4)(B); 40 C.F.R. section 122.41(i)(4); Wat. Code, sections 13267, 13383.)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. section 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. section 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses

are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. section 122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Central Valley Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. section 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. section 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. section 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Central Valley Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. section 122.41(m)(4)(i)(C).)
4. The Central Valley Water Board may approve an anticipated bypass, after considering its adverse effects, if the Central Valley Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. section 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit prior notice if possible, at least 10 days before the date of the bypass. The notice shall be sent to the Central Valley Water Board. As of 21 December 2020, all notices shall be submitted electronically to the initial recipient (State Water Board), defined in Standard Provisions – Reporting V.J below. Notices shall comply with 40 C.F.R. Part 3, section 122.22, and 40 C.F.R. Part 127. (40 C.F.R. section 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit a notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). The notice shall be sent to the Central Valley Water Board. As of 21 December 2020, all notices shall be submitted electronically to the initial recipient (State Water Board), defined in Standard Provisions – Reporting V.J below. Notices shall comply with 40 C.F.R. Part 3, section 122.22, and 40 C.F.R. Part 127. (40 C.F.R. section 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. section 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. section 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, thorough properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. section 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. section 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 C.F.R. section 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. section 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. section 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. section 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. section 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. section 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Central Valley Water Board. The Central Valley Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. section 122.41(l)(3); 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. section 122.41(j)(1).)
- B.** Monitoring must be conducted according to test procedures approved under 40 C.F.R. Part 136 for the analyses of pollutants unless another method is required under 40 C.F.R. subchapters N or O. Monitoring must be conducted according to sufficiently sensitive test methods approved under 40 C.F.R. Part 136 for the analysis of pollutants or pollutant parameters or as required under 40 C.F.R. chapter 1, subchapter N or O. For the purposes of this paragraph, a method is sufficiently sensitive when the method has the lowest ML of the analytical methods approved under 40 C.F.R. Part 136 or required under 40 C.F.R. chapter 1, subchapter N or O for the measured pollutant or pollutant parameter, or when:
1. The method minimum level (ML) is at or below the level of the most stringent effluent limitation established in the permit for the measured pollutant or pollutant parameter, and:
 - a. The method ML is at or below the level of the most stringent applicable water quality criterion for the measured pollutant or pollutant parameter, or;
 - b. The method ML is above the applicable water quality criterion but the amount of the pollutant or pollutant parameter in the facility's discharge is high enough that the method detects and quantifies the level of the pollutant or pollutant parameter in the discharge;

In the case of pollutants or pollutant parameters for which there are no approved methods under 40 C.F.R. Part 136 or otherwise required under 40 C.F.R. chapter 1, subchapters N or O, monitoring must be conducted according to a test procedure specified in this Order for such pollutants or pollutant parameters. (40 C.F.R. sections 122.21(e)(3), 122.41(j)(4); 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by 40 C.F.R. part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Central Valley Water Board Executive Officer at any time. (40 C.F.R. section 122.41(j)(2).)
- B.** Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements (40 C.F.R. section 122.41(j)(3)(i));
 2. The individual(s) who performed the sampling or measurements (40 C.F.R. section 122.41(j)(3)(ii));
 3. The date(s) analyses were performed (40 C.F.R. section 122.41(j)(3)(iii));
 4. The individual(s) who performed the analyses (40 C.F.R. section 122.41(j)(3)(iv));
 5. The analytical techniques or methods used (40 C.F.R. section 122.41(j)(3)(v)); and
 6. The results of such analyses. (40 C.F.R. section 122.41(j)(3)(vi).)
- C.** Claims of confidentiality for the following information will be denied (40 C.F.R. section 122.7(b)):
1. The name and address of any permit applicant or Discharger (40 C.F.R. section 122.7(b)(1)); and
 2. Permit applications and attachments, permits and effluent data. (40 C.F.R. section 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Central Valley Water Board, State Water Board, or U.S. EPA within a reasonable time, any information which the Central Valley Water Board, State Water Board, or U.S. EPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Central Valley Water Board, State Water Board, or U.S. EPA copies of

records required to be kept by this Order. (40 C.F.R. section 122.41(h); Wat. Code, sections 13267, 13383.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Central Valley Water Board, State Water Board, and/or U.S. EPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, V.B.5, and V.B.6 below. (40 C.F.R. section 122.41(k).)
2. All permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. (40 C.F.R. section 122.22(a)(1).)
3. All reports required by this Order and other information requested by the Central Valley Water Board, State Water Board, or U.S. EPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. section 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. section 122.22(b)(2)); and
 - c. The written authorization is submitted to the Central Valley Water Board and State Water Board. (40 C.F.R. section 122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Central Valley Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. section 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. section 122.22(d).)
6. Any person providing the electronic signature for such documents described in Standard Provision – V.B.1, V.B.2, or V.B.3 that are submitted electronically shall meet all relevant requirements of Standard Provisions – Reporting V.B, and shall ensure that all of the relevant requirements of 40 C.F.R. part 3 (Cross-Media Electronic Reporting) and 40 C.F.R. part 127 (NPDES Electronic Reporting Requirements) are met for that submission. (40 C.F.R section 122.22(e).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. section 122.41(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Central Valley Water Board or State Water Board for reporting the results of monitoring, sludge use, or disposal practices. As of 21 December 2016, all reports and forms must be submitted electronically to the initial recipient, defined in Standard Provisions – Reporting V.J, and comply with 40 C.F.R. part 3, section 122.22, and 40 C.F.R. part 127. (40 C.F.R. section 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under 40 C.F.R. part 136, or another method required for an industry-specific waste stream under 40 C.F.R. subchapters N or O, the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting

form specified by the Central Valley Water Board. (40 C.F.R. section 122.41(l)(4)(ii).)

4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. section 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. section 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A report shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The report shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports must include the data described above (with the exception of time of discovery) as well as the type of event (combined sewer overflows, sanitary sewer overflows, or bypass events), type of sewer overflow structure (e.g., manhole, combined sewer overflow outfall), discharge volumes untreated by the treatment works treating domestic sewage, types of human health and environmental impacts of the sewer overflow event, and whether the noncompliance was related to wet weather.

As of 21 December 2020 all reports related to combined sewer overflows, sanitary sewer overflows, or bypass events must be submitted electronically to the initial recipient (State Water Board) defined in Standard Provisions – Reporting V.J. The reports shall comply with 40 C.F.R. part 3. They may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. section 122.41(l)(6)(i).)

F. Planned Changes

The Discharger shall give notice to the Central Valley Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. section 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. section 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 C.F.R. section 122.41(l)(1)(ii).)

The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 C.F.R. section 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Central Valley Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with this Order's requirements. (40 C.F.R. section 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. For noncompliance events related to combined sewer overflows, sanitary sewer overflows, or bypass events, these reports shall contain the information described in Standard Provision – Reporting V.E and the applicable required data in appendix A to 40 C.F.R. part 127. The Central Valley Water Board may also require the Discharger to electronically submit reports not related to combined sewer overflows, sanitary sewer overflows, or bypass events under this section. (40 C.F.R. section 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Central Valley Water Board, State Water Board, or U.S. EPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. section 122.41(l)(8).)

J. Initial Recipient for Electronic Reporting Data

The owner, operator, or the duly authorized representative is required to electronically submit NPDES information specified in appendix A to 40 C.F.R. part 127 to the appropriate initial recipient, as determined by U.S. EPA, and as defined in 40 C.F.R. section 127.2(b). U.S. EPA will identify and publish the list of initial recipients on its website and in the Federal Register, by state and by NPDES data group [see 40 C.F.R. section 127.2(c)]. U.S. EPA will update and maintain this listing. (40 C.F.R. section 122.41(l)(9).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A.** The Central Valley Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13350, 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Central Valley Water Board as soon as they know or have reason to believe (40 C.F.R. section 122.42(a)):

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" (40 C.F.R. section 122.42(a)(1)):
 - a. 100 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. section 122.42(a)(1)(i));
 - b. 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony (40 C.F.R. section 122.42(a)(1)(ii));
 - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. section 122.42(a)(1)(iii)); or
 - d. The level established by the Central Valley Water Board in accordance with section 122.44(f). (40 C.F.R. section 122.42(a)(1)(iv).)
2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" (40 C.F.R. section 122.42(a)(2)):
 - a. 500 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. section 122.42(a)(2)(i));
 - b. 1 milligram per liter (mg/L) for antimony (40 C.F.R. section 122.42(a)(2)(ii));

- c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. section 122.42(a)(2)(iii)); or
- d. The level established by the Central Valley Water Board in accordance with section 122.44(f). (40 C.F.R. section 122.42(a)(2)(iv).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

I.	General Monitoring Provisions.....	E-2
II.	Monitoring Locations	E-3
III.	Influent Monitoring Requirements – NOT APPLICABLE	E-4
IV.	Effluent Monitoring Requirements	E-4
	A. Monitoring Location EFF-001 & EFF-002	E-4
V.	Whole Effluent Toxicity Testing Requirements	E-6
VI.	Land Discharge Monitoring Requirements	E-9
	A. Monitoring Location LND-001, LND-002, LND-005, and LND-006	E-9
	B. Monitoring Location LND-003 and LND-004	E-10
VII.	Recycling Monitoring Requirements -- NOT APPLICABLE	E-11
VIII.	Receiving Water Monitoring Requirements	E-11
	A. Monitoring Location RSW-001, RSW-002, RSW-003, and RSW-004.....	E-11
	B. Monitoring Locations MW-1 through MW-5.....	E-12
IX.	Other Monitoring Requirements.....	E-14
	A. Precipitation Monitoring	E-14
	B. Ash and Cooling Tower Solids Monitoring	E-14
	C. Effluent and Receiving Water Characterization	E-15
X.	Reporting Requirements.....	E-22
	A. General Monitoring and Reporting Requirements.....	E-22
	B. Self-Monitoring Reports (SMRs)	E-22
	C. Other Reports	E-26

Tables

Table E-1.	Monitoring Station Locations.....	E-3
Table E-2.	Effluent Monitoring-Monitoring Location EFF-001 & EFF-002.....	E-4
Table E-3	Chronic Toxicity Testing Dilution Series.....	E-7
Table E-4	Land Discharge Monitoring Requirements	E-9
Table E-5	Land Discharge Monitoring Requirements	E-10
Table E-6	Receiving Water Monitoring Requirements.....	E-11
Table E-7	Groundwater Monitoring Requirements	E-13
Table E-8	Precipitation Monitoring Requirements	E-14
Table E-9	Ash Monitoring Requirements	E-14
Table E-10	Effluent and Receiving Water Characterization Monitoring	E-17
Table E-11	Monitoring Periods and Reporting Schedule.....	E-23
Table E-12	Technical Reports	E-27

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations (40 C.F.R. section 122.48) requires that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Central Valley Water Board to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements that implement federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A.** Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and the approval of the Central Valley Water Board.
- B.** Final effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to mixing with the receiving waters. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
- C.** Chemical, bacteriological, and bioassay analyses of any material required by this Order shall be conducted by a laboratory accredited for such analyses by the State Water Resources Control Board (State Water Board), Division of Drinking Water (DDW; formerly the Department of Public Health), in accordance with the provision of Water Code section 13176. Laboratories that perform sample analyses must be identified in all monitoring reports submitted to the Central Valley Water Board. In the event an accredited laboratory is not available to the Discharger for any onsite field measurements such as pH, dissolved oxygen (DO), turbidity, temperature, and residual chlorine, such analyses performed by a non-accredited laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program for any onsite field measurements such as pH, DO, turbidity, temperature, and residual chlorine must be kept onsite in the treatment facility laboratory and shall be available for inspection by Central Valley Water Board staff. The Discharger must demonstrate sufficient capability (qualified and trained employees, properly calibrated and maintained field instruments, etc.) to adequately perform these field measurements. The Quality Assurance-Quality Control Program must conform to U.S. EPA guidelines or to procedures approved by the Central Valley Water Board.
- D.** Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary, at least yearly, to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.

- E. Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this Monitoring and Reporting Program.
- F. Laboratories analyzing monitoring samples shall be accredited by DDW, in accordance with the provision of Water Code section 13176 and must include quality assurance/quality control data with their reports.
- G. The Discharger shall ensure that the results of the Discharge Monitoring Report-Quality Assurance (DMR-QA) Study or the most recent Water Pollution Performance Evaluation Study are submitted annually to the State Water Resources Control Board at the following address:

State Water Resources Control Board
Quality Assurance Program Officer
Office of Information Management and Analysis
1001 I Street, Sacramento, CA 95814
- H. The Discharger shall file with the Central Valley Water Board technical reports on self-monitoring performed according to the detailed specifications contained in this Monitoring and Reporting Program.
- I. The results of all monitoring required by this Order shall be reported to the Central Valley Water Board, and shall be submitted in such a format as to allow direct comparison with the limitations and requirements of this Order. Unless otherwise specified, discharge flows shall be reported in terms of the monthly average and the daily maximum discharge flows.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
SW-5	EFF-001	Outfall structure immediately prior to discharge to Canyon Creek. Latitude: 40° 52' 31.82" N, Longitude: 121° 42' 17.95" W
SW-6	EFF-002	Outfall structure immediately prior to discharge to the unnamed tributary to Canyon Creek. Latitude: 40° 52' 49.71" N, Longitude: 121° 42' 18.01" W
--	RSW-001	<monitoring location description> Latitude: <xx.xxxxx°> - Longitude: <-xxx.xxxxx°>
--	RSW-002	In Canyon Creek, 200 feet downstream from Discharge Point D-001.°
	RSW-003	<monitoring location description> Latitude: <xx.xxxxx°> - Longitude: <-xxx.xxxxx°>

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
	RSW-004	<monitoring location description> Latitude: <xx.xxxxx°> - Longitude: <-xxx.xxxxx°>
--	MW-001 through MW-005	Groundwater monitoring wells
--	LND-001	Log yard sprinkle water in the Log Yard Retention Pond
--	LND-002	Fire Pond located on the south side of the cogeneration plant.
--	LND-003	Evaporation Pond-1 located in the southeast corner of the Facility.
--	LND-004	Evaporation Pond 2 located in the southeast corner of the Facility.
--	LND-005	Substation Pond located on the north side of the Facility.
--	LND-006	South Retention Pond on the south side of the Facility.

The North latitude and West longitude information in Table E-1 are approximate for administrative purposes.

III. INFLUENT MONITORING REQUIREMENTS – NOT APPLICABLE

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location EFF-001 & EFF-002

1. The Discharger shall monitor industrial storm water, as defined in Attachment A, at Monitoring Location EFF-001 and EFF-002 when discharges to Canyon Creek occur as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level:

Table E-2. Effluent Monitoring-Monitoring Location EFF-001 & EFF-002

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow	MGD	Meter	1/Day
Temperature	°C	Grab	1/Week
Dissolved Oxygen	mg/L	Grab	1/Week
Oil and Grease	mg/L	Grab	2/Year
pH	Standard units	Grab	1/Week
Total Suspended Solids	mg/L	Grab	1/Week
Priority Pollutants and Other Constituents of Concern	See Section IX.C	See Section IX.C	See Section IX.C

Parameter	Units	Sample Type	Minimum Sampling Frequency
Aluminum, Total Recoverable and Dissolved	µg/L	Grab	2/Month
Chemical Oxygen Demand	mg/L	Grab	1/Month
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Week
Hardness, Total (as CaCO ₃)	mg/L	Grab	1/Month
Iron, Total Recoverable and Dissolved	µg/L	Grab	2/Month
Manganese, Total Recoverable and Dissolved	µg/L	Grab	2/Month
Settleable Solids	ml/L	Grab	1/Week
Tannins and Lignins	mg/L	Grab	1/Month
Turbidity	NTU	Grab	1/Week

2. **Table E-2 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-2:
- Applicable to all parameters.** Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136 or by methods approved by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.
 - A hand-held field meter may be used for **temperature** and **pH**, provided the meter utilizes a U.S. EPA-approved algorithm/method and is calibrated and maintained in accordance with the manufacturer's instructions. A calibration and maintenance log for each meter used for monitoring required by this Monitoring and Reporting Program shall be maintained at the Facility.
 - Priority Pollutants.** For priority pollutant constituents the reporting level shall be consistent with Sections 2.4.2 and 2.4.3 of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (See Attachment E, section IX.C).

- d. **Hardness** samples shall be collected concurrently with metals samples.
- e. **Aluminum.** Monitoring for aluminum can be done using either total or acid-soluble (inductively coupled plasma/atomic emission spectrometry or inductively coupled plasma/mass spectrometry) analysis methods, as supported by U.S. EPA's Ambient Water Quality Criteria for Aluminum document (EPA 440/5-86-008), or other standard methods that exclude aluminum silicate particles as approved by the Executive Officer.
- f. If the discharge is intermittent rather than continuous, then on the first day of each such intermittent discharge, the Discharger shall monitor and record for all of the constituents listed above, after which the frequencies of analysis given in the schedule shall apply for the duration of each such intermittent discharge. In no event shall the Discharger be required to monitor and record data more often than twice the frequencies listed in the schedule.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity Testing. The Discharger shall conduct acute toxicity testing to determine whether the effluent is contributing acute toxicity to the receiving water. The Discharger shall meet the acute toxicity testing requirement:

- 1. **Monitoring Frequency** – The Discharger shall perform semi-annual acute toxicity testing.
- 2. **Sample Types** – The Discharger may use flow-through or static renewal testing. For static renewal testing, the samples shall be grab samples and shall be representative of the volume and quality of the discharge. Routine effluent samples shall be taken at Monitoring Location EFF-002. If discharge from EFF-001 has occurred during the monitoring period, sampling shall also be conducted at EFF-001.
- 3. **Test Species** – Test species shall be rainbow trout (*Oncorhynchus mykiss*).
- 4. **Methods** – The acute toxicity testing samples shall be analyzed using EPA-821-R-02-012, Fifth Edition. Temperature, total residual chlorine, and pH shall be recorded at the time of sample collection. No pH adjustment may be made unless approved by the Executive Officer.
- 5. **Test Failure** – If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger must re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.

B. Chronic Toxicity Testing. The Discharger shall meet the chronic toxicity testing requirements:

1. **Monitoring Frequency** – The Discharger shall perform chronic toxicity testing once per permit term.
2. **Sample Types** – Effluent samples shall be grab samples and shall be representative of the volume and quality of the discharge. The effluent samples shall be taken at Monitoring Location EFF-002. If discharge from EFF-001 occurs during the permit term, sampling shall also be conducted at EFF-001 if discharging at SW-5, and RSW-003 if discharging at SW-6. The receiving water control shall be a grab sample obtained from Monitoring Location RSW-001, as identified in this Monitoring and Reporting Program.
3. **Sample Volumes** – Adequate sample volumes shall be collected to provide renewal water to complete the test in the event that the discharge is intermittent.
4. **Test Species** – Chronic toxicity testing measures sublethal (e.g., reduced growth, reproduction) and/or lethal effects to test organisms exposed to an effluent compared to that of the control organisms. The Discharger shall conduct chronic toxicity tests with:
 - a. The cladoceran, water flea, *Ceriodaphnia dubia* (survival and reproduction test);
 - b. The fathead minnow, *Pimephales promelas* (larval survival and growth test); and
 - c. The green alga, *Selenastrum capricornutum* (growth test).
5. **Methods** – The presence of chronic toxicity shall be estimated as specified in Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002.
6. **Reference Toxicant** – As required by the SIP, all chronic toxicity tests shall be conducted with concurrent testing with a reference toxicant and shall be reported with the chronic toxicity test results.
7. **Dilutions** – For routine and compliance chronic toxicity monitoring, the chronic toxicity testing shall be performed using the dilution series identified in Table E-5, below. A receiving water control or laboratory water control may be used as the diluent.

Table E-3 Chronic Toxicity Testing Dilution Series

Samples	Dilution%	Dilution%	Dilution%	Dilution%	Dilution%	Controls
% Effluent	100	75	50	25	12.5	0
% Control Water	0	25	50	75	87.5	100

8. **Test Failure** – The Discharger must re-sample and re-test as soon as possible, but no later than fourteen (14) days after receiving notification of a test failure. A test failure is defined as follows:
 - a. The reference toxicant test or the effluent test does not meet all test acceptability criteria as specified in the Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA/821-R-02-013, October 2002 (Method Manual), and its subsequent amendments or revisions; or
 - b. The percent minimum significant difference (PMSD) measured for the test exceeds the upper PMSD bound variability criterion in the Method Manual.
- C. **WET Testing Notification Requirements.** The Discharger shall notify the Central Valley Water Board within 24-hours after the receipt of test results indicating an exceedance of the acute toxicity effluent limitation.
- D. **WET Testing Reporting Requirements.** All toxicity test reports shall include the contracting laboratory's complete report provided to the Discharger and shall be in accordance with the appropriate "Report Preparation and Test Review" sections of the method manuals. At a minimum, whole effluent toxicity monitoring shall be reported as follows:
 1. Chronic WET Reporting. Routing and compliance chronic toxicity monitoring results shall be reported to the Central Valley Water Board with the monthly self-monitoring report, and shall contain, at minimum:
 - a. The results expressed in TUC, measured as 100/NOEC, and also measured as 100/LC50, 100/EC25, 100/IC25, and 100/IC50, as appropriate.
 - b. The statistical methods used to calculate endpoints;
 - c. The statistical output page, which includes the calculation of the percent minimum significant difference (PMSD);
 - d. The dates of sample collection and initiation of each toxicity test; and
 - e. The results compared to the numeric toxicity monitoring trigger.

Additionally, the monthly self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TUC, and organized by test species, type of test (survival, growth or reproduction), and monitoring type, i.e., routine or compliance monitoring.
 2. Acute WET Reporting. Acute toxicity test results shall be submitted with the monthly discharger self-monitoring reports and reported as percent survival.

3. Quality Assurance (QA). The Discharger must provide the following information for QA purposes:
 - a. Results of the applicable reference toxicant data with the statistical output page giving the species, NOEC, LOEC, type of toxicant, dilution water used, concentrations used, PMSD, and dates tested.
 - b. The reference toxicant control charts for each endpoint, which include summaries of reference toxicant tests performed by the contracting laboratory.
 - c. Any information on deviations or problems encountered and how they were dealt with.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

A. Monitoring Location LND-001, LND-002, LND-005, and LND-006

1. The Discharger shall monitor the Log Yard Retention Pond, Fire Pond, Substation Pond, and South Retention Pond at Monitoring Locations LND-001, LND-002, LND-005, and LND-006 in accordance with Table E-6 and the testing requirements described in section VI.A.2 below:

Table E-4 Land Discharge Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Freeboard	Feet	Visual	1/Week
pH	standard units	Grab	1/Month
Dissolved Oxygen	mg/L	Grab	1/Month
Settled Matter Depth	Feet, inches	Visual	1/Year prior to rainy season
Arsenic, Total Recoverable	µg/L	Grab	1/Quarter
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Month
Chemical Oxygen Demand	mg/L	Grab	1/Quarter
Total Nitrogen	mg/L	Grab	1/Quarter
Nitrate Nitrogen, Total (as N)	mg/L	Grab	1/Quarter
Total Kjeldahl Nitrogen	mg/L	Grab	1/Quarter
Fixed Dissolved Solids	mg/L	Grab	1/Quarter

Parameter	Units	Sample Type	Minimum Sampling Frequency
Total Dissolved Solids	mg/L	Grab	1/Quarter
Iron, Total Recoverable and Dissolved	µg/L	Grab	1/Quarter
Manganese, Total Recoverable and Dissolved	µg/L	Grab	1/Quarter
Standard Minerals	µg/L	Grab	1/Year

2. **Table E-4 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-4:

- a. **Applicable to all parameters.** Pollutants shall be analyzed using the analytical methods described in 40 C.F.R. part 136 or by methods approved by the Central Valley Water Board or the State Water Board.

B. Monitoring Location LND-003 and LND-004

1. The Discharger shall monitor **Evaporation Pond-1** and **Evaporation Pond-2** at Monitoring Locations **LND-003** and **LND-004** as follows:

Table E-5 Land Discharge Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Freeboard	Feet	Visual	1/Week
pH	standard units	Grab	1/Month
Settled Matter Depth	Feet, inches	Visual	1/Year prior to rainy season
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Month

2. **Table E-5 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-5:

- a. **Applicable to all parameters.** Pollutants shall be analyzed using the analytical methods described in 40 C.F.R. part 136 or by methods approved by the Central Valley Water Board or the State Water Board.

VII. RECYCLING MONITORING REQUIREMENTS -- NOT APPLICABLE

VIII. RECEIVING WATER MONITORING REQUIREMENTS

A. Monitoring Location RSW-001, RSW-002, RSW-003, and RSW-004

1. The Discharger shall monitor Canyon Creek during periods of discharge at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004 as follows:

Table E-6 Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Flow	cfs	Visual	1/Week
pH	standard units	Grab	1/Week
Priority Pollutants and Other Constituents of Concern	various	See Section IX.C	1/Permit Term
Dissolved Oxygen	mg/L	Grab	1/Week
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Week
Hardness, Total (as CaCO ₃)	mg/L	Grab	1/Month
Iron, Total Recoverable	µg/L	Grab	2/Month
Manganese, Total Recoverable	µg/L	Grab	2/Month
Temperature	°C	Grab	1/Week
Turbidity	NTU	Grab	1/Week

2. **Table E-6 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-6:
 - a. Samples shall be collected during the first 24 hours from the first discharge after the dry season during daytime business hours and according to the sampling frequency in Table E-6 thereafter. Receiving water sampling shall be concurrent with effluent (storm water) sampling, when applicable.
 - b. Pollutants shall be analyzed using the analytical methods described in 40 C.F.R. part 136 or by methods approved by the Central Valley Water Board or the State Water Board.
 - c. For priority pollutant constituents the reporting level shall be consistent with Sections 2.4.2 and 2.4.3 of the Policy for Implementation of Toxics

Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (See Attachment E, section IX.C). Priority pollutant testing is not required at RSW-002 and RSW-004

- d. Monitoring for priority pollutants and other constituents of concern shall be conducted at Monitoring Location RSW-001 only.
3. In conducting the receiving water sampling, a log shall be kept of the receiving water conditions throughout the reach bounded by RSW-001, RSW-002, RSW-003, and RSW-004 when discharging to Canyon Creek. Attention shall be given to the presence of:
 - a. Floating or suspended matter;
 - b. Discoloration;
 - c. Bottom deposits;
 - d. Aquatic life;
 - e. Visible films, sheens, or coatings;
 - f. Fungi, slimes, or objectionable growths; and
 - g. Potential nuisance conditions.

Notes on receiving water conditions shall be summarized in the monitoring report.

B. Monitoring Locations MW-1 through MW-5

1. Prior to construction and/or beginning a sampling program of any new groundwater monitoring wells, the Discharger shall submit plans and specifications to the Central Valley Water Board for approval. Once installed, all new wells shall be added to the monitoring network (which currently consists of Monitoring Well Nos. MW-1, MW-2, MW-3, MW-4, and MW-5,) and shall be sampled and analyzed according to the schedule below. All samples shall be collected using approved EPA methods. Water table elevations shall be calculated to determine groundwater gradient and direction of flow.
2. The methods of analysis and the detection limits used must be appropriate for the expected concentrations. For the monitoring of any constituent or parameter that is found in concentrations which produce more than 90% non-numerical determinations (i.e., "trace" or "ND") in data from background monitoring points for that medium, the analytical method having the lowest method detection limit (MDL) shall be selected from among those methods which would provide valid results in light of any matrix effects or interferences.

3. Prior to sampling, the groundwater elevations shall be measured and the wells shall be purged by low flow method by United States Environmental Protection Agency Low-Flow (Minimal Drawdown) Ground-Water Sampling Procedures EPA/540/s-95/504 until temperature, pH, and electrical conductivity have stabilized. Depth to groundwater shall be measured to the nearest 0.01 feet. Groundwater monitoring at MW-1, MW-2, MW-3, MW-4, and MW-5, and any new groundwater monitoring wells shall include, at a minimum, the following:

Table E-7 Groundwater Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency
Depth to Groundwater	±0.01 feet	Measurement	1/Quarter
Groundwater Elevation	±0.01 feet	Calculate	1/Quarter
Gradient	feet/feet	Calculate	1/Quarter
Gradient Direction	degrees	Calculate	1/Quarter
Arsenic, Dissolved	µg/L	Grab	1/Quarter
Electrical Conductivity @ 25°C	µmhos/cm	Grab	1/Quarter
Iron, Dissolved	µg/L	Grab	1/Quarter
Manganese, Dissolved	µg/L	Grab	1/Quarter
Total Dissolved Solids	mg/L	Grab	1/Quarter
Fixed Dissolved Solids	mg/L	Grab	1/Quarter
pH	standard units	Grab	1/Quarter
Total Nitrogen	mg/L	Grab	1/Quarter
Nitrate Nitrogen, Total (as N)	mg/L	Grab	1/Quarter
Total Kjeldahl Nitrogen	mg/L	Grab	1/Quarter
Standard Minerals	µg/L	Grab	1/Year

2. **Table E-7 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-7:
 - a. **Prior to sampling,** the groundwater elevations shall be measured, and the wells shall be purged by low flow purge method until temperature, pH, and electrical conductivity have stabilized. Depth to groundwater shall be measured to the nearest 0.01 feet.
 - b. **Groundwater elevation** shall be determined based on depth-to-water measurements from a surveyed measuring point elevation on the well. The groundwater elevation shall be used to calculate the direction and gradient of groundwater flow, which must be reported.
 - c. **Applicable to all parameters.** Pollutants shall be analyzed using the analytical methods described in 40 CFR part 136 or by methods approved

by the Central Valley Water Board or the State Water Board. In addition, if requested by the Discharger, the sample type may be modified by the Executive Officer to another 40 CFR part 136 allowed sample type.

- d. **Standard minerals** shall include the following: boron, calcium, iron, sulfate, magnesium, potassium, sodium, chloride, manganese, phosphorus, total alkalinity (including alkalinity series), and hardness, and include verification that the analysis is complete (i.e., cation/anion balance).

IX. OTHER MONITORING REQUIREMENTS

A. Precipitation Monitoring

1. Precipitation information shall be collected as follows and reported in the monthly SMR: Add the following paragraphs only if the Discharger has a pretreatment program.

Table E-8 Precipitation Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling
Precipitation	Inches	Gauge	1/Day

B. Ash and Cooling Tower Solids Monitoring

1. Wood ash information shall be collected and reported in the SMRs in accordance with the table below.

Table E-9 Ash Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling
Ash Volume Generated	Dry-tons ³	Continuous	1/Month
Ash Volume Stored at Facility	Dry-tons ³	Continuous	1/Month
Ash Volume Removed from Facility	Dry-tons ³	Continuous	1/Month
Ash Liming Capacity	Equiv % CaCO ₃	Composite	2/Year
Ash Total Phosphorous	mg/kg	Composite	2/Year
Moisture Content	% Moisture	Composite	2/Year
pH	standard units	Composite	2/Year
CAM 17 Metals	mg/kg	Composite	2/Year
TCDD-Equivalents	pg/g	Composite	1/Year

2. **Table E-9 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-9:
 - a. Pollutants shall be analyzed using the analytical methods described in 40 C.F.R. part 136 or by methods approved by the Central Valley Water Board or the State Water Board.
 - b. California Administrative Manual (i.e. CCR) metals: antimony, arsenic, barium, beryllium, cadmium, chromium, cobalt, copper, lead, mercury, molybdenum, nickel, selenium, silver, thallium, vanadium, and zinc.
 - c. In accordance with CCR Title 22 testing procedures.
 - d. Dioxin equivalents, also known as the TEQ, is a calculated value that reflects the combined effect of dioxin and furan compounds (cogeners). Results for dioxin TEQ shall include all congeners.
 - e. Upon Executive Officer approval, sampling frequency may be reduced after two consecutive years of data has been submitted.
 - f. A&L Western Agricultural Laboratories' Neutralizing value of liming materials (or percent calcium carbonate equivalency-CCE).
 - g. Units may be reported in volume or weight measurement.
3. The Discharger shall record on a monthly basis the following information about wood ash removed from the Facility and submit in an annual SMR no later than 1 April of each year:
 - a. final end user name, address, and disposal location or soil amendment application area (except as described in item c. below for intermediate producers), and
 - b. volume and/or weight of ash for each location/area (except as described in item c. below for intermediate producers).
 - c. the name, address, and volume and/or weight of ash sold or supplied to an intermediate producer for use in the manufacture of commercial soil amendment products. (Note: Final application area information for end users purchasing commercial soil amendment products is not required.)

C. Effluent and Receiving Water Characterization

1. The Discharger shall conduct effluent and receiving water characterization monitoring in accordance with Table E-10 and the testing requirements described in section IX.D.2 below.

2. **Table E-10 Testing Requirements.** The Discharger shall comply with the following testing requirements when monitoring for the parameters described in Table E-10.
- a. **Monitoring.** Samples shall be collected from the effluent and upstream receiving water (Monitoring Locations EFF-001 (if discharge has occurred at this location during the permit term), EFF-002 and RSW-001) and analyzed for the constituents listed in Table E-10, below. Monitoring shall be conducted once during the first three months of discharge during the 2020/2021 wet season. Constituents shall be collected and analyzed consistent with the Discharger's Analytical Methods Report (MRP, X.D.2) using sufficiently sensitive analytical methods and Reporting Levels per the SSM Rule specified in 40 C.F.R. 122.21(e)(3) and 122.44(i)(1)(iv). The "Reporting Level" is synonymous with the "Method Minimum Level" described in the SSM Rule. Each individual monitoring event shall provide representative sample results for the effluent and upstream receiving water.
 - b. The Discharger is not required to conduct effluent monitoring for constituents that have already been sampled in a given month, as required in Table E-3, except for hardness, pH, and temperature, which shall be conducted concurrently with the effluent sampling.
 - c. **Concurrent Sampling.** Effluent and receiving water sampling shall be performed at approximately the same time, on the same date.
 - d. **Sample Type.** All samples shall be taken as grab samples.
 - e. **Bis (2-ethylhexyl) phthalate.** In order to verify if bis (2-ethylhexyl) phthalate is truly present, the Discharger shall take steps to assure that sample containers, sampling apparatus, and analytical equipment are not sources of the detected contaminant.
 - f. **Analytical Methods Report Certification.** Prior to beginning the Effluent and Receiving Water Characterization monitoring, the Discharger shall provide a certification acknowledging the scheduled start date of the Effluent and Receiving Water Characterization monitoring and confirming that samples will be collected and analyzed as described in the previously submitted Analytical Methods Report. If there are changes to the previously submitted Analytical Methods Report, the Discharger shall outline those changes. A one-page certification form will be provided by Central Valley Water Board staff with the permit's Notice of Adoption that the Discharger can use to satisfy this requirement. The certification form shall be submitted electronically via CIWQS submittal by the due date in the Technical Reports Table.

Table E-10 Effluent and Receiving Water Characterization Monitoring

VOLATILE ORGANICS

CTR Number	Volatile Organic Parameters	CAS Number	Units	Effluent Sample Type
25	2-Chloroethyl vinyl Ether	110-75-8	µg/L	Grab
17	Acrolein	107-02-8	µg/L	Grab
18	Acrylonitrile	107-13-1	µg/L	Grab
19	Benzene	71-43-2	µg/L	Grab
20	Bromoform	75-25-2	µg/L	Grab
21	Carbon Tetrachloride	56-23-5	µg/L	Grab
22	Chlorobenzene	108-90-7	µg/L	Grab
24	Chloroethane	75-00-3	µg/L	Grab
26	Chloroform	67-66-3	µg/L	Grab
35	Methyl Chloride	74-87-3	µg/L	Grab
23	Dibromochloromethane	124-48-1	µg/L	Grab
27	Dichlorobromomethane	75-27-4	µg/L	Grab
36	Methylene Chloride	75-09-2	µg/L	Grab
33	Ethylbenzene	100-41-4	µg/L	Grab
89	Hexachlorobutadiene	87-68-3	µg/L	Grab
34	Methyl Bromide (Bromomethane)	74-83-9	µg/L	Grab
94	Naphthalene	91-20-3	µg/L	Grab
38	Tetrachloroethylene (PCE)	127-18-4	µg/L	Grab
39	Toluene	108-88-3	µg/L	Grab
40	trans-1,2-Dichloroethylene	156-60-5	µg/L	Grab
43	Trichloroethylene (TCE)	79-01-6	µg/L	Grab
44	Vinyl Chloride	75-01-4	µg/L	Grab
21	Methyl-tert-butyl ether (MTBE)	1634-04-4	µg/L	Grab
41	1,1,1-Trichloroethane	71-55-6	µg/L	Grab
42	1,1,2-Trichloroethane	79-00-5	µg/L	Grab
28	1,1-Dichloroethane	75-34-3	µg/L	Grab
30	1,1-Dichloroethylene (DCE)	75-35-4	µg/L	Grab
31	1,2-Dichloropropane	78-87-5	µg/L	Grab
32	1,3-Dichloropropylene	542-75-6	µg/L	Grab
37	1,1,2,2-Tetrachloroethane	79-34-5	µg/L	Grab
101	1,2,4-Trichlorobenzene	120-82-1	µg/L	Grab
29	1,2-Dichloroethane	107-06-2	µg/L	Grab
75	1,2-Dichlorobenzene	95-50-1	µg/L	Grab
76	1,3-Dichlorobenzene	541-73-1	µg/L	Grab
77	1,4-Dichlorobenzene	106-46-7	µg/L	Grab

SEMI-VOLATILE ORGANICS

CTR Number	Semi-Organic Volatile Parameters	CAS Number	Units	Effluent Sample Type
60	Benzo(a)Anthracene	56-55-3	µg/L	Grab
85	1,2-Diphenylhydrazine	122-66-7	µg/L	Grab
45	2-Chlorophenol	95-57-8	µg/L	Grab
46	2,4-Dichlorophenol	120-83-2	µg/L	Grab
47	2,4-Dimethylphenol	105-67-9	µg/L	Grab
49	2,4-Dinitrophenol	51-28-5	µg/L	Grab
82	2,4-Dinitrotoluene	121-14-2	µg/L	Grab
55	2,4,6-Trichlorophenol	88-06-2	µg/L	Grab
83	2,6-Dinitrotoluene	606-20-2	µg/L	Grab
50	2-Nitrophenol	88-75-5	µg/L	Grab
71	2-Chloronaphthalene	91-58-7	µg/L	Grab
78	3,3-Dichlorobenzidine	91-94-1	µg/L	Grab
62	Benzo(b)Fluoranthene	205-99-2	µg/L	Grab
52	4-Chloro-3-methylphenol	59-50-7	µg/L	Grab
48	2-Methyl-4,6-Dinitrophenol	534-52-1	µg/L	Grab
51	4-Nitrophenol	100-02-7	µg/L	Grab
69	4-Bromophenyl Phenyl Ether	101-55-3	µg/L	Grab
72	4-Chlorophenyl Phenyl Ether	7005-72-3	µg/L	Grab
56	Acenaphthene	83-32-9	µg/L	Grab
57	Acenaphthylene	208-96-8	µg/L	Grab
58	Anthracene	120-12-7	µg/L	Grab
59	Benzidine	92-87-5	µg/L	Grab
61	Benzo(a)Pyrene	50-32-8	µg/L	Grab
63	Benzo(ghi)Perylene	191-24-2	µg/L	Grab
64	Benzo(k)Fluoranthene	207-08-9	µg/L	Grab
65	Bis (2-Chloroethoxy) Methane	111-91-1	µg/L	Grab
66	Bis (2-Chloroethyl) Ether	111-44-4	µg/L	Grab
67	Bis (2-Chloroisopropyl) Ether	108-60-1	µg/L	Grab
68	Bis(2-Ethylhexyl) Phthalate	117-81-7	µg/L	Grab
70	Butylbenzyl Phthalate	85-68-7	µg/L	Grab
73	Chrysene	218-01-9	µg/L	Grab
81	Di-n-butyl Phthalate	84-74-2	µg/L	Grab
84	Di-n-Octyl Phthalate	117-84-0	µg/L	Grab
74	Dibenzo(a,h)anthracene	53-70-3	µg/L	Grab
79	Diethyl Phthalate	84-66-2	µg/L	Grab
80	Dimethyl Phthalate	131-11-3	µg/L	Grab
86	Fluoranthene	206-44-0	µg/L	Grab
87	Fluorene	86-73-7	µg/L	Grab
88	Hexachlorobenzene	118-74-1	µg/L	Grab
90	Hexachlorocyclopentadiene	77-47-4	µg/L	Grab
91	Hexachloroethane	67-72-1	µg/L	Grab
92	Indeno(1,2,3-cd) Pyrene	193-39-5	µg/L	Grab
93	Isophorone	78-59-1	µg/L	Grab

CTR Number	Semi-Organic Volatile Parameters	CAS Number	Units	Effluent Sample Type
98	N-Nitrosodiphenylamine	86-30-6	µg/L	Grab
96	N-Nitrosodimethylamine	62-75-9	µg/L	Grab
97	N-Nitrosodi-n-Propylamine	621-64-7	µg/L	Grab
95	Nitrobenzene	98-95-3	µg/L	Grab
53	Pentachlorophenol (PCP)	87-86-5	µg/L	Grab
99	Phenanthrene	85-01-8	µg/L	Grab
54	Phenol	108-95-2	µg/L	Grab
100	Pyrene	129-00-0	µg/L	Grab

INORGANICS

CTR Number	Inorganic Parameters	CAS Number	Units	Effluent Sample Type
NL	Aluminum	7429-90-5	µg/L	Grab
1	Antimony, Total Recoverable	7440-36-0	µg/L	Grab
2	Arsenic, Total Recoverable	7440-38-2	µg/L	Grab
15	Asbestos	1332-21-4	µg/L	Grab
3	Beryllium, Total Recoverable	7440-41-7	µg/L	Grab
4	Cadmium, Total Recoverable	7440-43-9	µg/L	Grab
5a (III)	Chromium, Total	7440-47-3	µg/L	Grab
6	Copper, Total Recoverable	7440-50-8	µg/L	Grab
14	Iron, Total Recoverable	7439-89-6	µg/L	Grab
7	Lead, Total Recoverable	7439-92-1	µg/L	Grab
8	Mercury, Total Recoverable	7439-97-6	µg/L	Grab
NL	Mercury, Methyl	22967-92-6	µg/L	Grab
NL	Manganese, Total Recoverable	7439-96-5	µg/L	Grab
9	Nickel, Total Recoverable	7440-02-0	µg/L	Grab
10	Selenium, Total Recoverable	7782-49-2	µg/L	Grab
11	Silver, Total Recoverable	7440-22-4	µg/L	Grab
12	Thallium, Total Recoverable	7440-28-0	µg/L	Grab
13	Zinc, Total Recoverable	7440-66-6	µg/L	Grab

NON-METALS/MINERALS

CTR Number	Non-Metal/Mineral Parameters	CAS Number	Units	Effluent Sample Type
NL	Boron	7440-42-8	µg/L	Grab
NL	Chloride	16887-00-6	mg/L	Grab
14	Cyanide, Total (as CN)	57-12-5	µg/L	Grab
NL	Phosphorus, Total (as P)	7723-14-0	mg/L	Grab
NL	Sulfate	14808-79-8	mg/L	Grab
NL	Sulfide (as S)	5651-88-7	mg/L	Grab

PESTICIDES/PCBs/DIOXINS

CTR Number	Pesticide/PCB/Dioxin Parameters	CAS Number	Units	Effluent Sample Type
110	4,4-DDD	72-54-8	µg/L	Grab
109	4,4-DDE	72-55-9	µg/L	Grab
108	4,4-DDT	50-29-3	µg/L	Grab
112	alpha-Endosulfan	959-98-8	µg/L	Grab
103	alpha-BHC (Benzene hexachloride)	319-84-6	µg/L	Grab
102	Aldrin	309-00-2	µg/L	Grab
113	beta-Endosulfan	33213-65-9	µg/L	Grab
104	beta-BHC (Benzene hexachloride)	319-85-7	µg/L	Grab
107	Chlordane	57-74-9	µg/L	Grab
106	delta-BHC (Benzene hexachloride)	319-86-8	µg/L	Grab
111	Dieldrin	60-57-1	µg/L	Grab
114	Endosulfan Sulfate	1031-07-8	µg/L	Grab
115	Endrin	72-20-8	µg/L	Grab
116	Endrin Aldehyde	7421-93-4	µg/L	Grab
117	Heptachlor	76-44-8	µg/L	Grab
118	Heptachlor Epoxide	1024-57-3	µg/L	Grab
105	gamma-BHC (Benzene hexachloride or Lindane)	58-89-9	µg/L	Grab
119	Polychlorinated Biphenyl (PCB) 1016	12674-11-2	µg/L	Grab
120	PCB 1221	11104-28-2	µg/L	Grab
121	PCB 1232	11141-16-5	µg/L	Grab
122	PCB 1242	53469-21-9	µg/L	Grab
123	PCB 1248	12672-29-6	µg/L	Grab
124	PCB 1254	11097-69-1	µg/L	Grab
125	PCB 1260	11096-82-5	µg/L	Grab
126	Toxaphene	8001-35-2	µg/L	Grab
16	2,3,7,8-TCDD (Dioxin)	1746-01-6	mg/L	Grab

CONVENTIONAL PARAMETERS

CTR Number	Conventional Parameters	CAS Number	Units	Effluent Sample Type
NL	pH	--	SU	Grab
NL	Temperature	--	°C	Grab

NON-CONVENTIONAL PARAMETERS

CTR Number	Nonconventional Parameters	CAS Number	Units	Effluent Sample Type
NL	Foaming Agents (MBAS)	MBAS	mg/L	Grab
NL	Hardness (as CaCO ₃)	471-34-1	mg/L	Grab
NL	Specific Conductance (Electrical Conductivity or EC)	EC	µmhos /cm	Grab
NL	Total Dissolved Solids (TDS)	TDS	mg/L	Grab

CTR Number	Nonconventional Parameters	CAS Number	Units	Effluent Sample Type
NL	Dissolved Organic Carbon (DOC)	DOC	mg/L	Grab

NUTRIENTS

CTR Number	Nutrient Parameters	CAS Number	Units	Effluent Sample Type
7	Ammonia (as N)	7664-41-7	mg/L	Grab
8	Nitrate (as N)	14797-55-8	mg/L	Grab
9	Nitrite (as N)	14797-65-0	mg/L	Grab

OTHER CONSTITUENTS OF CONCERN

CTR Number	Other Constituents of Concern	CAS Number	Units	Effluent Sample Type
NL	1,2,3-Trichloropropane (TCP)	96-18-4	ug/L	Grab
NL	Trichlorofluoromethane	75-69-4	µg/L	Grab
NL	1,1,2-Trichloro-1,2,2-Trifluoroethane	76-13-1	µg/L	Grab
NL	Styrene	100-42-5	µg/L	Grab
NL	Xylenes	1330-20-7	µg/L	Grab
NL	Barium	7440-39-3	µg/L	Grab
NL	Fluoride	16984-48-8	mg/L	Grab
NL	Molybdenum	7439-98-7	µg/L	Grab
NL	Tributyltin	688-73-3	µg/L	Grab
NL	Alachlor	15972-60-8	µg/L	Grab
NL	Atrazine	1912-24-9	µg/L	Grab
NL	Bentazon	25057-89-0	µg/L	Grab
NL	Carbofuran	1563-66-2	µg/L	Grab
NL	2,4-D	94-75-7	µg/L	Grab
NL	Dalapon	75-99-0	µg/L	Grab
NL	1,2-Dibromo-3-chloropropane (DBCP)	96-12-8	µg/L	Grab
NL	Di(2-ethylhexyl)adipate	103-23-1	µg/L	Grab
NL	Dinoseb	88-85-7	µg/L	Grab
NL	Diquat	85-00-7	µg/L	Grab
NL	Endothal	145-73-3	µg/L	Grab
NL	Ethylene Dibromide (EDB)	106-93-4	µg/L	Grab
NL	Methoxychlor	72-43-5	µg/L	Grab
NL	Molinate (Ordram)	2212-67-1	µg/L	Grab
NL	Oxamyl	23135-22-0	µg/L	Grab
NL	Picloram	1918-02-1	µg/L	Grab
NL	Simazine (Princep)	122-34-9	µg/L	Grab
NL	Thiobencarb	28249-77-6	µg/L	Grab
NL	2,4,5-TP (Silvex)	93-72-1	µg/L	Grab
NL	Chlorpyrifos	2921-88-2	µg/L	Grab
NL	Diazinon	333-41-5	µg/L	Grab

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. Upon written request of the Central Valley Water Board, the Discharger shall submit a summary monitoring report. The report shall contain both tabular and graphical summaries of the monitoring data obtained during the previous year(s).
3. **Compliance Time Schedules.** For compliance time schedules included in the Order, the Discharger shall submit to the Central Valley Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Central Valley Water Board by letter when it returns to compliance with the compliance time schedule.
4. The Discharger shall report to the Central Valley Water Board any toxic chemical release data it reports to the State Emergency Response Commission within 15 days of reporting the data to the Commission pursuant to section 313 of the "Emergency Planning and Community Right to Know Act" of 1986.

B. Self-Monitoring Reports (SMRs)

1. The Discharger shall electronically submit SMRs using the State Water Board's [California Integrated Water Quality System \(CIWQS\) Program website](http://www.waterboards.ca.gov/water_issues/programs/ciwqs/) (http://www.waterboards.ca.gov/water_issues/programs/ciwqs/). The CIWQS website will provide additional information for SMR submittal in the event there will be a planned service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Discharger shall submit monthly SMRs including the results of all required monitoring using U.S. EPA-approved test methods or other test methods specified in this Order. SMRs are to include all new monitoring results obtained since the last SMR was submitted. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR. Monthly SMRs are required even if there is no discharge. If no discharge occurs during the month, the monitoring report must be submitted stating that there has been no discharge.

3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-11 Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	Submit with monthly SMR
1/Day	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	Submit with monthly SMR
1/Week	Permit effective date	Sunday through Saturday	Submit with monthly SMR
2/Month	Permit effective date	1st day of calendar month through last day of calendar month	First day of second calendar month following month of sampling
1/Month	Permit effective date	1st day of calendar month through last day of calendar month	First day of second calendar month following month of sampling
1/Quarter	Permit effective date	1 January through 31 March 1 April through 30 June 1 July through 30 September 1 October through 31 December	1 May 1 August 1 November 1 February of following year
2/Year	Permit effective date	1 January through 30 June 1 July through 31 December	1 August 1 February of following year
1/Year	Permit effective date	1 January through 31 December	1 February of following year

4. **Reporting Protocols.** The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current laboratory's Method Detection Limit (MDL), as determined by the procedure in 40 C.F.R. part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).

- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the Minimum Level (ML) value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
5. **Multiple Sample Data.** When determining compliance with an AMEL or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
- a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.
6. **The Discharger shall submit SMRs** in accordance with the following requirements:

- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
 - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the waste discharge requirements; exceedances of storm water action levels; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations and exceedances of storm water action levels must include a description of the requirement that was violated or exceeded and a description of the violation or exceedance.
 - c. The Discharger shall attach all final laboratory reports from all contracted commercial laboratories, including quality assurance/quality control information, with all its SMRs for which sample analyses were performed.
7. The Discharger shall submit in the SMRs calculations and reports in accordance with the following requirements:
- a. **Dissolved Oxygen Receiving Water Limitations.** The Discharger shall report monthly in the self-monitoring report the dissolved oxygen concentrations in the effluent (EFF-001 or EFF-002) and the receiving water (RSW-001, RSW-002, RSW-003, and RSW-004).
 - b. **Turbidity Receiving Water Limitations.** The Discharger shall calculate and report the turbidity increase in the receiving water applicable to the natural turbidity condition specified in section V.A.17.a-e. of the Waste Discharge Requirements.
 - c. **Temperature Receiving Water Limitations.** The Discharger shall calculate and report the temperature increase in the receiving water based on the difference in temperature at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004.
 - d. **Log Yard Sprinkling.** The Discharger shall report the dates on which log yard sprinkling occurred in the monthly SMR.
 - e. **Groundwater Monitoring Reports.** The reports shall be prepared by or under the direction of registered professionals competent and proficient in the fields pertinent to the required activities, and shall bear the professional's signature and stamp. Each quarterly report shall contain:

- i. Results of the monitoring of the groundwater in tabular format;
- ii. A narrative description of all preparatory, monitoring, sampling, and analytical testing activities for the groundwater monitoring. The narrative shall be sufficiently detailed to verify compliance with this Order. The narrative shall be supported by field logs for each well documenting depth to groundwater; parameters measured before, during, and after purging; method of purging; calculation of casing volume; and total volume of water purged;
- iii. Calculation of groundwater elevations, determination of groundwater flow direction and gradient on the date of measurement, comparison of previous flow direction and gradient data, and discussion of seasonal trends if any;
- iv. Summary data tables of historical and current groundwater elevations;
- v. Copies of laboratory analytical report(s) for groundwater monitoring

C. Other Reports

1. **Annual Operations Report.** The Discharger shall submit a written report to the Central Valley Water Board, electronically via CIWQS submittal, containing the following by the due date in the Technical Reports Table:
 - a. The names, certificate grades, and general responsibilities of all persons employed at the Facility.
 - b. The names and telephone numbers of persons to contact regarding the plant for emergency and routine situations.
 - c. A statement certifying when the flow meter(s) and other monitoring instruments and devices were last calibrated, including identification of who performed the calibration.
 - d. A statement certifying whether the current operation and maintenance manual, and contingency plan, reflect the wastewater treatment plant as currently constructed and operated, and the dates when these documents were last revised and last reviewed for adequacy.
 - e. The Discharger may also be requested to submit an annual report to the Central Valley Water Board with both tabular and graphical summaries of the monitoring data obtained during the previous year. Any such request shall be made in writing. The report shall discuss the compliance record. If violations have occurred, the report shall also discuss the corrective actions taken and planned to bring the discharge into full compliance with the waste discharge requirements.

- f. The Discharger shall report the results of any special studies, acute and chronic toxicity testing, PMP, and Pollution Prevention Plan required by Special Provisions VI.C. The Discharger shall submit reports with the first monthly SMR scheduled to be submitted on or immediately following the report due date.
2. **Technical Report Submittals.** This Order includes requirements to submit a Report of Waste Discharge (ROWD), special study technical reports, progress reports, and other reports identified in the MRP (hereafter referred to collectively as “technical reports”). The Technical Reports Table and subsequent table notes below summarize all technical reports required by this Order and the due dates for submittal. All technical reports shall be submitted electronically via CIWQS submittal. Technical reports should be uploaded as a PDF, Microsoft Word, or Microsoft Excel file attachment.

Table E-12 Technical Reports

Report #	Technical Report	Due Date	CIWQS Report Name
Intentionally left blank	Standard Reporting Requirements	Intentionally left blank	Intentionally left blank
1	Report of Waste Discharge	31 May 2024	ROWD
2	Analytical Methods Report	20 June 2020	MRP X.D.3
3	Annual Operations Report	1 February 2021	MRP X.D.4
4	Annual Operations Report	1 February 2022	MRP X.D.4
5	Annual Operations Report	1 February 2023	MRP X.D.4
6	Annual Operations Report	1 February 2024	MRP X.D.4
7	Annual Operations Report	1 February 2025	MRP X.D.4
Intentionally left blank	Other Reports	Intentionally left blank	Intentionally left blank
8	Best Management Practice (BMP) Improvement Evaluation	Within 60 days following storm water action level exceedance or receiving water violation	WDR VI.C.2.a
9	Antidegradation Re-evaluation	21 October 2023	WDR VI.C.2.g
10	Downgradient Monitoring Wells Evaluation	1 June 2021	WDR VI.C.2.c
11	Facility Water Balance Evaluation Work Plan	7 October 2020	WDR VI.C.2.b
12	Facility Water Balance Evaluation Final Report	7 October 2021	WDR VI.C.3.c
13	Storm Water Pollution Prevention Plan (SWPPP)	7 October 2020	WDR VI.C.3.b

Report #	Technical Report	Due Date	CIWQS Report Name
15	Annual Ash Monitoring Report	1 February 2021	WDR VI.C.6.a.ii
16	Annual Ash Monitoring Report	1 February 2022	WDR VI.C.6.a.ii
17	Annual Ash Monitoring Report	1 February 2023	WDR VI.C.6.a.ii
18	Annual Ash Monitoring Report	1 February 2024	WDR VI.C.6.a.ii
19	Annual Ash Monitoring Report	1 February 2025	WDR VI.C.6.a.ii

ATTACHMENT F – FACT SHEET

Table of Contents

I.	Permit Information	F-3
II.	Facility Description	F-4
	A. Description of Wastewater and Biosolids Treatment and Controls	F-4
	B. Discharge Points and Receiving Waters.....	F-7
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	F-7
	D. Compliance Summary.....	F-7
	E. Planned Changes	F-8
III.	Applicable Plans, Policies, and Regulations.....	F-8
	A. Legal Authorities	F-8
	B. California Environmental Quality Act (CEQA).....	F-9
	C. State and Federal Laws, Regulations, Policies, and Plans	F-9
	D. Impaired Water Bodies on CWA 303(d) List	F-12
	E. Other Plans, Policies and Regulations.....	F-12
IV.	Rationale For Effluent Limitations and Discharge Specifications.....	F-13
	A. Discharge Prohibitions.....	F-14
	B. Technology-Based Effluent Limitations.....	F-17
	1. Scope and Authority.....	F-17
	2. Applicable Technology-Based Effluent Limitations	F-18
	C. Water Quality-Based Effluent Limitations (WQBEL's) and Storm Water Action Levels	F-19
	1. Scope and Authority.....	F-19
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-20
	3. Determining the Need for Storm Water Action Levels.....	F-22
	4. WQBEL Calculations	F-26
	5. Whole Effluent Toxicity (WET)	F-26
	D. Final Effluent Limitation Considerations.....	F-27
	1. Mass-based Effluent Limitations	F-27
	2. Averaging Periods for Effluent Limitations	F-27
	3. Satisfaction of Anti-Backsliding Requirements.....	F-28
	4. Antidegradation Policies	F-29
	5. Stringency of Requirements for Individual Pollutants.....	F-31
	E. Interim Effluent Limitations – Not Applicable.....	F-32
	F. Land Discharge Specifications – Not Applicable.....	F-32
	G. Recycling Specifications – Not Applicable	F-32
V.	Rationale for Receiving Water Limitations	F-32
	A. Surface Water	F-32
	B. Groundwater	F-32
VI.	Rationale For Provisions	F-32
	A. Standard Provisions.....	F-32
	B. Special Provisions.....	F-33
	1. Reopener Provisions.....	F-33
	2. Special Studies and Additional Monitoring Requirements.....	F-34
	3. Best Management Practices and Pollution Prevention	F-35

4. Construction, Operation, and Maintenance Specifications.....	F-36
5. Special Provisions for Publicly-Owned Treatment Works (POTWs) – Not Applicable	F-36
6. Other Special Provisions.....	F-36
7. Compliance Schedules – Not Applicable	F-36
VII. Rationale for Monitoring and Reporting Requirements.....	F-36
A. Influent Monitoring – Not Applicable	F-36
B. Effluent Monitoring.....	F-36
C. Whole Effluent Toxicity Testing Requirements	F-37
D. Receiving Water Monitoring.....	F-38
1. Surface Water.....	F-38
2. Groundwater	F-38
E. Other Monitoring Requirements.....	F-39
VIII. Public Participation	F-39
A. Notification of Interested Persons	F-40
B. Written Comments	F-40
C. Public Hearing	F-40
D. Reconsideration of Waste Discharge Requirements.....	F-40
E. Information and Copying.....	F-41
F. Register of Interested Persons	F-41
G. Additional Information	F-41

Tables

Table F-1. Facility Information	F-3
Table F-2. Historic Effluent Limitations	F-7
Table F-3 Basin Plan Beneficial Uses	F-9
Table F-4. Summary of Technology-based Effluent Limitations	F-19
Table F-5. Summary of Final Effluent Limitations	F-31

ATTACHMENT F – FACT SHEET

As described in section II.B of this Order, the Central Valley Water Board incorporates this Fact Sheet as findings of the Central Valley Water Board supporting the issuance of this Order. This Fact Sheet discusses the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the Facility.

Table F-1. Facility Information

Waste Discharge ID:	5A452015001
CIWQS Facility Place ID:	256964
Discharger:	Sierra Pacific Industries
Name of Facility:	Burney Division
Facility Address:	36336 Highway 299 East
Facility City, State Zip:	Burney, CA 96013
Facility County:	Shasta County
Facility Contact, Title and Phone Number:	Jeremy Higgins, Environmental Manager, (530) 378-8179
Authorized Person to Sign and Submit Reports:	Jeremy Higgins, Environmental Manager, (530) 378-8179
Mailing Address:	P.O. Box 2677, Burney, CA 96013
Billing Address:	Same as Mailing Address
Type of Facility:	Electric Services (SIC 4911) and Sawmill and Planing Mill (SIC 2421)
Major or Minor Facility:	Minor
Threat to Water Quality:	2
Complexity:	A
Pretreatment Program:	Not Applicable
Recycling Requirements:	Not Applicable
Facility Permitted Flow:	Not Applicable
Facility Design Flow:	Not Applicable
Watershed:	Lower Pit
Receiving Water:	Canyon Creek
Receiving Water Type:	Inland surface water

- A. Sierra Pacific Industries (hereinafter Discharger) is the owner of Burnley Division (hereinafter Facility), a sawmill and wood-burning cogeneration facility.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B. The Facility discharges wastewater to Canyon Creek, a water of the United States, tributary to Burnley Creek and the Pit River within the Lower Pit watershed. The Discharger was previously regulated by Order R5-2015-0071 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0003981 adopted on 5 June 2015 and **expires** on 31 July 2020. Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.
- C. The Discharger filed a report of waste discharge (ROWD) and submitted an application for reissuance of its waste discharge requirements (WDR's) and NPDES permit on 19 December 2019. **The application was deemed complete on <Date Application Complete>.**
- E. Regulations at 40 C.F.R. section 122.46 limit the duration of NPDES permits to a fixed term not to exceed five years. Accordingly, Table 3 of this Order limits the duration of the discharge authorization. Under 40 C.F.R. section 122.6(d), States authorized to administer the NPDES program may administratively continue State-issued permits beyond their expiration dates until the effective date of the new permits, if State law allows it. Pursuant to California Code of Regulations, title 23, section 2235.4, the terms and conditions of an expired permit are automatically continued pending reissuance of the permit if the Discharger complies with all federal NPDES requirements for continuation of expired permits.

II. FACILITY DESCRIPTION

The Facility is a sawmill and wood-burning cogeneration facility located in Burnley, CA. Approximately 75% of the 216-acres, including all areas of industrial truck traffic and the log yard, is asphalt paved. The balance of the site is covered by vegetation.

The cogeneration plant produces 20 megawatts (MW) of electric power. Sawmill operations consist of log scaling, wet and dry log storage, mechanical log debarking, sawmill, planing mill, kilns, lumber storage, aboveground storage of petroleum hydrocarbons, equipment fueling and maintenance, storage of used equipment, paved and unpaved roadways, a truck shop, and an office. Wood waste from the sawmill is delivered to the cogeneration plant by conveyor.

A. Description of Wastewater and Biosolids Treatment and Controls

1. Drainage Area NPDES 1-1

Drainage Area NPDES 1-1 is predominantly pervious ground surrounding the Retention Pond and the Ash Storage Area. Storm water does not run off from this area and infiltrates into the pervious ground.

2. Ash Management

Ash generated at the cogen is collected in a concrete bunker and cooled with water. Once ash is cooled and sufficient quantity has accumulated, the ash is transported to the Ash Storage Area and retained onsite until delivery to the agricultural customer. Ash is licensed by the California Department of Food and Agriculture for sale as a byproduct that is beneficially reused as a soil amendment and is certified as an organic input material by CDFA and OMRI. The Location(s) of on-site storage is shown in Attachment C.

3. Drainage Area NPDES 1-2

Drainage Area NPDES 1-2 is predominantly paved ground and facilitates a number of industrial processes, including the cogeneration facility, and finished lumber storage and shipping. Storm water from this area is collected in a storm drain system that drains to the Fire Pond.

4. Drainage Area NPDES 1-3

Drainage Area NPDES 1-3 is predominantly paved ground surrounding the sawmill. Storm water from this area is collected in storm drains and conveyed to the Fire Pond.

5. Fire Pond

The Fire Pond has a catchment area of approximately XX-acres and has a capacity of approximately XX-acre-feet (YY million gallons). Storm water collected in the Fire Pond is aerated to encourage aerobic treatment of organic constituents to reduce COD. Water from the Fire Pond is pumped to the Log Yard Retention Pond.

6. Drainage Areas NPDES 2-1 through NPDES 2-4

Drainage Area NPDES 2-1 through NPDES 2-4 is predominantly paved ground facilitating the log deck and the sawmill log infeed. Storm water from this area flows over the pavement or into a collection ditch that conveys it to the Log Yard Retention Pond.

7. Log Yard Retention Pond

The Log Yard Retention Pond has a catchment area of approximately XX-acres in addition to the Fire Pond catchment area, and therefore has a total catchment area of XX-acres. The Log Yard Retention Pond has a capacity of approximately XX-acre-feet (YY million gallons). Storm water collected in the Log Yard Retention Pond

is aerated to encourage aerobic treatment of organic constituents to reduce COD. Storm water from the Log Yard Retention Pond is pumped to the Land Application Area.

8. Land Application Area

The Land Application Area is approximately XX-acres of forest land adjacent to the sawmill. The forest land topography is gently undulating and slopes toward the log deck. Storm water pumped to the Land Application Area is applied through a network of sprinklers and then pools up and either infiltrates or runs over the forest floor back to a collection ditch. The land application process is a BMP that removes Tannin and Lignin, COD, TSS, and metals.

9. Drainage Areas 1 through 5

Drainage Areas 1 through 5 are covered under the IGP. These areas facilitate the lumber planer, dry kilns, maintenance area, shipping area, Truck Shop, and adjacent non-industrial areas. Drainage Areas 1 through 5 discharge through IGP discharge Locations SW-1 through SW-4

10. Sawmill

The Facility processes approximately 168 million board feet of construction grade lumber annually. Logs are delivered by truck to the sawmill and are stacked on a 25-acre paved log yard. During the dry summer months, the logs are sprinkled with water to prevent the development of blue stain and end checking. When the wet season begins, the log yard sprinklers are shut off. Sprinkling usually ends in late October or early November; however, sprinkling may occur outside that timeframe when air temperatures exceed 50°F. Excess log yard runoff drains to the log yard pond system. Log yard runoff contains bark, sawdust, tannins and lignins, dissolved organics, and settleable and suspended solids.

The Facility includes a 2.2 million gallon log yard retention pond, a 0.94 million gallon evaporation pond, a 1.17 million gallon evaporation pond, a 1.18 million gallon substation pond, a 2.96 million gallon fire pond, and a 2.62 million gallon south retention pond (see site plan in Attachment C). Water stored in any one pond can ultimately be conveyed to other ponds for use (except for the two evaporation ponds from which stored water cannot be redrawn). All retention pond water is used to sprinkle logs in the log yard area during the dry season or during any extended dry periods throughout the year, used in sawmill operations, or used in cogeneration plant operations. Retention pond water contains process water pollutants including tannins and lignins. This Order prohibits discharges from the ponds.

11. Cogeneration Plant

The cogeneration plant component of the Facility consists of a wood fuel storage area, a biomass fire (wood fueled) boiler, steam turbine, water treatment system, cooling tower, oil and chemical storage, and ash storage. The primary fuel source for

the cogeneration plant is wood waste from the sawmill and wood waste from off-site sources. Natural gas is used as a supplementary fuel for startup and flame stabilization for the cogeneration plant's boilers. The cogeneration plant requires process water to supply the boiler and cooling tower system. Supply groundwater is treated through reverse osmosis and chemical treatment for supplying boiler feedwater. The cogeneration plant wastes include: fuel storage leachate, boiler water blowdown, cooling tower blowdown, cooling tower treatment sludge, ash, and used petroleum products. Ash is transported to private agricultural lands for use as a soil amendment. Boiler blowdown, cooling tower blowdown, and reject water from the reverse osmosis equipment is discharged to the retention and evaporation ponds.

B. Discharge Points and Receiving Waters

1. The Facility is located in Section 24, T35N, R2E, MDB&M, as shown in Attachment B, a part of this Order.
2. Industrial storm water from the Log Yard Retention Pond can be discharged at Discharge Point SW-005 to Canyon Creek, a water of the United States and a tributary to Burney Creek and the Pit River at a point latitude 40° 52' 49.71" N and longitude 121° 42' 18.01" W.
3. Industrial storm water from the Land Application Area is collected in a conveyance ditch then a pipe and discharged at Discharge Point SW-006 to Canyon Creek, a water of the United States and a tributary to Burney Creek and the Pit River at a point latitude 40° 52' 31.82" N and longitude 121° 42' 17.95" W.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in Order R5-2015-0071 for discharges from Discharge Point SW-005 (Monitoring Location EFF-001) and representative monitoring data from the term of Order R5-2015-0071 are as follows:

Table F-2. Historic Effluent Limitations

Parameter	Units	Historic Effluent Limitations	Highest Average Monthly Discharge	Highest Average Weekly Discharge
pH	standard units	6.00-9.00	9.96	9.96
Settleable Solids	ml/L	AMEL 0.10 MDEL 0.20	.7	.7

D. Compliance Summary

The Central Valley Water Board issued a Administrative Civil Liability (ACL) Complaint on 27 April 2017 which proposed to assess a civil liability of \$12,000

against the Discharger for an unpermitted discharge of process wastewater to surface water that occurred in January 2017. The Discharger paid the mandatory minimum penalty of \$12,000.

E. Planned Changes

Fire Pond

The Discharger is proposing to alter how storm water is conveyed, ponded, and discharged through the Fire Pond. It is proposed that storm water in the Fire Pond will be drained to the storm water drainage system at drain inlet SW-2-CB4 to be discharged through IGP discharge point SW-2, or similar path. This will allow storm water runoff from the sawmill area that is collected in the Fire Pond to be managed under the IGP and reduce the hydraulic load and management complexity associated with the management through the Log Yard Retention Pond and Land Application Area with discharge through SW-6. BMPs will be implemented to prevent leachate from the ash storage area from entering the Fire Pond. Storm water from the processes (cogen, sawmill) draining to the Fire Pond are consistent with the coverage under the IGP. This planned change is not permitted under this Order, but may be permitted once this Order is rescinded and coverage under the IGP is obtained.

Land Application Area

Although the IGP permits discharge of storm water associated with a log deck and sawmill operations, the Facility's discharge has historically exhibited toxicity, for which reason an NPDES permit was required. With the implementation of the new storm water BMPs and water management strategy, the Discharger intends to show the potential to comply with the storm water NALs at SW-6 and that the treated water from the Land Application Area does not exhibit toxicity.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order serves as WDR's pursuant to article 4, chapter 4, division 7 of the California Water Code (commencing with section 13260). This Order is also issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. EPA and chapter 5.5, division 7 of the Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this Facility to surface waters.

B. California Environmental Quality Act (CEQA)

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA, (commencing with section 21100) of Division 13 of the Public Resources Code.

C. State and Federal Laws, Regulations, Policies, and Plans

1. Water Quality Control Plans. Requirements of this Order specifically implement the applicable Water Quality Control Plans.

- a. Basin Plan. The Central Valley Water Board adopted a Water Quality Control Plan for the Sacramento River and San Joaquin River Basins, Fifth Edition, May 2018 (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements in this Order implement the Basin Plan.

The Basin Plan at section 2.1 states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan in Table 2-1, section 2, does not specifically identify beneficial uses for Canyon Creek, but does identify present and potential uses for the Pit River, from the mouth of Hat Creek to Shasta Lake, to which Canyon Creek, via Burney Creek, is tributary. In addition, the Basin Plan implements State Water Board Resolution 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Thus, beneficial uses applicable to Canyon Creek are as follows:

Table F-3 Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Canyon Creek	Existing: Municipal and domestic supply (MUN); agricultural supply, including irrigation and stock watering (AGR); hydropower generation (POW); water contact recreation, including canoeing and rafting (REC-1); non-contact water recreation (REC-2); cold freshwater habitat (COLD); warm and cold spawning, reproduction, and/or early development (SPWN); and wildlife habitat. Potential: Warm freshwater habitat (WARM).
--	Groundwater	Existing:

Discharge Point	Receiving Water Name	Beneficial Use(s)
		Municipal and domestic supply (MUN); agricultural supply (AGR); industrial service supply (IND); and industrial process supply (PRO).

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** U.S. EPA adopted the NTR on 22 December 1992, and later amended it on 4 May 1995 and 9 November 1999. About forty criteria in the NTR applied in California. On 18 May 2000, U.S. EPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on 13 February 2001. These rules contain federal water quality criteria for priority pollutants.
3. **State Implementation Policy.** On 2 March 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on 28 April 2000, with respect to the priority pollutant criteria promulgated for California by the U.S. EPA through the NTR and to the priority pollutant objectives established by the Central Valley Water Board in the Basin Plan. The SIP became effective on 18 May 2000, with respect to the priority pollutant criteria promulgated by the U.S. EPA through the CTR. The State Water Board adopted amendments to the SIP on 24 February 2005, that became effective on 13 July 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
4. **Antidegradation Policy.** Federal regulation 40 C.F.R. section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16 ("Statement of Policy with Respect to Maintaining High Quality of Waters in California") (State Anti-Degradation Policy). The State Anti-Degradation Policy is deemed to incorporate the federal antidegradation policy where the federal policy applies under federal law. The State Anti-Degradation Policy requires that existing water quality be maintained unless degradation is justified based on specific findings. The Central Valley Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge must be consistent with the antidegradation provision of 40 C.F.R. section 131.12 and the State Anti-Degradation Policy. The Board finds this order is consistent with the Federal and State Water Board antidegradation regulations and policy. This order also requires downgradient wells to be evaluated in a Downgradient Monitoring Wells Evaluation Report per Special Provision VI.C.2.d. As a

result of this evaluation, and any additional groundwater monitoring conducted during the term of this Order, the Discharger is further required to submit an Antidegradation Re-evaluation that must be submitted with its ROWD that is to be provided to the Board as required by Special Provision VI.C.2.e.

5. **Anti-Backsliding Requirements.** Sections 402(o) and 303(d)(4) of the CWA and federal regulations at 40 C.F.R. section 122.44(l) restrict backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.
6. **Domestic Water Quality.** In compliance with Water Code section 106.3, it is the policy of the State of California that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes. This Order promotes that policy by requiring discharges to meet maximum contaminant levels designed to protect human health and ensure that water is safe for domestic use.
7. **Endangered Species Act Requirements.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code, sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The Discharger is responsible for meeting all requirements of the applicable Endangered Species Act.
8. **Storm Water Requirements.** U.S. EPA promulgated federal regulations for storm water on 16 November 1990 in 40 C.F.R. parts 122, 123, and 124. The NPDES Industrial Storm Water Program regulates storm water discharges from sawmills and planing mills. Sawmills and planing mills are applicable industries under the storm water program and are obligated to comply with the federal regulations.

The discharge of industrial storm water from the log yard could be regulated under the General Industrial Storm Water Permit. However, due to the complexity of the Facility operations and unique threats to water quality, the Central Valley Water Board has elected to regulate these discharges with an individual NPDES permit. Therefore, discharges of industrial storm water from the log yard are not covered under the General Industrial Storm Water Permit and are covered under this Order.

9. **Mosquito Abatement.** The California Health and Safety Code establishes requirements for the management of water ponds necessary for the control of mosquitos and other disease vectors. The Shasta County Mosquito and Vector Control District has jurisdiction and enforcement responsibility

pursuant to this code. The Discharger has entered into a memorandum of understanding that is pay in lieu of abatement, which compensates the District for specific mosquito abatement practices that achieve compliance with the CA H&S Code.

D. Impaired Water Bodies on CWA 303(d) List

1. Under section 303(d) of the 1972 CWA, states, territories and authorized tribes are required to develop lists of water quality limited segments. The waters on these lists do not meet water quality standards, even after point sources of pollution have installed the minimum required levels of pollution control technology. On 11 October 2011 U.S. EPA gave final approval to California's 2008-2010 section 303(d) List of Water Quality Limited Segments. The Basin Plan references this list of Water Quality Limited Segments (WQLSs), which are defined as "...those sections of lakes, streams, rivers or other fresh water bodies where water quality does not meet (or is not expected to meet) water quality standards even after the application of appropriate limitations for point sources (40 C.F.R. part 130, et seq.)." The Basin Plan also states, "Additional treatment beyond minimum federal standards will be imposed on dischargers to [WQLSs]. Dischargers will be assigned or allocated a maximum allowable load of critical pollutants so that water quality objectives can be met in the segment." Canyon Creek is not listed as impaired on the 2014 and 2016 303(d) list.
2. At the time of this permit renewal, there are no approved TMDLs with waste load allocations (WLAs) that apply to this Facility.
3. The 303(d) listings and TMDL's have been considered in the development of the Order. A pollutant-by-pollutant evaluation of each pollutant of concern is described in section VI.C.3 of this Fact Sheet.

E. Other Plans, Policies and Regulations

1. **Title 27.** The discharge authorized herein and the treatment and storage facilities associated with the discharge of treated municipal wastewater, except for discharges of residual sludge and solid waste, are exempt from the requirements of Title 27, California Code of Regulations (CCR), section 20005 et seq (hereafter Title 27). The exemption, pursuant to Title 27 CCR section 20090(a), is based on the following:

20090(b) Wastewater – Discharges of wastewater to land, including but not limited to evaporation ponds, percolation ponds, or subsurface leachfields if the following conditions are met:

- (1) the Central Valley Water Board has issued WDRs, or waived such issuance;

(2) the discharge is in compliance with the applicable water quality control plan; and

(3) the wastewater does not need to be managed as a hazardous waste .

The Facility ponds are unlined, and wastewater contained in the ponds percolates to the underlying groundwater; however, groundwater monitoring data indicates that the discharge is in compliance with the Basin Plan, and thus, meets precondition (2). Some impacts observed in downgradient wells have been questioned due to the location of the downgradient wells being on or near historic, abandoned log storage ponds with significant decomposing organics in the subsurface. This Order requires the discharger to evaluate the existing downgradient monitoring wells and install new downgradient monitoring wells, if necessary, to assess impacts and ensure the discharge continues to be in compliance with the Basin Plan. Additionally, this Order requires the Discharger to continue collecting groundwater monitoring data. =

2. **Wood Ash.** Pursuant to state and federal regulations wood ash, classified as non-hazardous solid waste, may be beneficially reused as an agricultural soil amendment, or other appropriate use. This Order does not authorize storage, transportation, or disposal of ash or other wastes characterized as hazardous wastes. Appropriate separate regulatory coverage must be secured for such activities.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

Effluent limitations and toxic and pretreatment effluent standards established pursuant to sections 301 (Effluent Limitations), 302 (Water Quality Related Effluent Limitations), 304 (Information and Guidelines), and 307 (Toxic and Pretreatment Effluent Standards) of the CWA and amendments thereto are applicable to the discharge.

The CWA mandates the implementation of effluent limitations that are as stringent as necessary to meet water quality standards established pursuant to state or federal law [33 U.S.C., section 1311(b)(1)(C); 40 C.F.R. section 122.44(d)(1)]. NPDES permits must incorporate discharge limits necessary to ensure that water quality standards are met. This requirement applies to narrative criteria as well as to criteria specifying maximum amounts of particular pollutants. Pursuant to federal regulations, 40 C.F.R. section 122.44(d)(1)(i), NPDES permits must contain limits that control all pollutants that “are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard, including state narrative criteria for water quality.” Federal regulations, 40 C.F.R. section 122.44(d)(1)(vi), further provide that “[w]here a state has not established a water quality criterion for a specific chemical pollutant that is present in an effluent at a concentration that causes, has the reasonable potential to cause, or contributes to an excursion above a narrative criterion within an applicable State water quality standard, the permitting authority must establish effluent limits.”

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: 40 C.F.R. section 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 C.F.R. section 122.44(d) requires that permits include WQBEL's to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water where numeric water quality objectives have not been established. The Basin Plan at page 4-27, contains an implementation policy, "Policy for Application of Water Quality Objectives", that specifies that the Central Valley Water Board "will, on a case-by-case basis, adopt numerical limitations in orders which will implement the narrative objectives." This Policy complies with 40 C.F.R. section 122.44(d)(1). With respect to narrative objectives, the Central Valley Water Board must establish effluent limitations using one or more of three specified sources, including: (1) U.S. EPA's published water quality criteria, (2) a proposed state criterion (i.e., water quality objective) or an explicit state policy interpreting its narrative water quality criteria (i.e., the Central Valley Water Board's "Policy for Application of Water Quality Objectives")(40 C.F.R. section 122.44(d)(1)(vi)(A), (B) or (C)), or (3) an indicator parameter.

The Basin Plan includes numeric site-specific water quality objectives and narrative objectives for toxicity, chemical constituents, discoloration, radionuclides, and tastes and odors. The narrative toxicity objective states: "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life." (Basin Plan at section 3.1.20) The Basin Plan states that material and relevant information, including numeric criteria, and recommendations from other agencies and scientific literature will be utilized in evaluating compliance with the narrative toxicity objective. The narrative chemical constituents' objective states that waters shall not contain chemical constituents in concentrations that adversely affect beneficial uses. At minimum, "...water designated for use as domestic or municipal supply (MUN) shall not contain concentrations of chemical constituents in excess of the maximum contaminant levels (MCLs)" in Title 22 of CCR. The Basin Plan further states that, to protect all beneficial uses, the Central Valley Water Board may apply limits more stringent than MCLs. The narrative tastes and odors objective states: "Water shall not contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to domestic or municipal water supplies or to fish flesh or other edible products of aquatic origin, or that cause nuisance, or otherwise adversely affect beneficial uses."

A. Discharge Prohibitions

- 1. Prohibition III.A (No discharge or application of waste other than that described in this Order).** This prohibition is based on Water Code section 13260 that requires filing of a ROWD before discharges can occur. The Discharger submitted a ROWD for the discharges described in this Order; therefore, discharges not described in this Order are prohibited.

2. **Prohibition III.B (No bypasses or overflow of untreated wastewater, except under the conditions at CFR section 122.41(m)(4)).** As stated in section I.G of Attachment D, Standard Provisions, this Order prohibits bypass from any portion of the treatment facility. Federal regulations, 40 C.F.R. section 122.41(m), define “bypass” as the intentional diversion of waste streams from any portion of a treatment facility. This section of the federal regulations, 40 C.F.R. section 122.41(m)(4), prohibits bypass unless it is unavoidable to prevent loss of life, personal injury, or severe property damage. In considering the Regional Water Board’s prohibition of bypasses, the State Water Board adopted a precedential decision, Order No. WQO 2002-0015, which cites the federal regulations, 40 C.F.R. section 122.41(m), as allowing bypass only for essential maintenance to assure efficient operation.
3. **Prohibition III.C (No controllable condition shall create a nuisance).** This prohibition is based on Water Code section 13050 that requires water quality objectives established for the prevention of nuisance within a specific area. The Basin Plan prohibits conditions that create a nuisance
4. **Prohibition III.D (No discharge of recycle water from log yard sprinkling, commingled recycle and storm water, cooling tower blowdown, boiler blowdown, boiler feedwater treatment system effluent, or other waste of recognizable sawmill or cogeneration origin).** Consistent with Order R5-2015-0071, this Order prohibits discharges of recycle water from log yard sprinkling, commingled recycle and storm water, cooling tower blowdown, boiler blowdown, boiler feedwater treatment system effluent, or other waste of recognizable sawmill or cogeneration origin.
5. **Prohibition III.E (No discharge of storm water leachate from wood fuel stockpiles to surface waters or surface water drainage courses).** Consistent with Order R5-2015-0071, this Order prohibits discharges of storm water leachate from wood fuel stockpiles to surface water or surface water drainage courses. This Order requires the Discharger to implement BMP’s to prevent these discharges.
6. **Prohibition III.F (No discharge of ash, bark, sawdust, wood, or any waste recognized as originating from cogeneration operations).** Consistent with Order R5-2015-0071, this Order prohibits the discharge of ash, bark, sawdust, wood, or any waste recognized as originating from cogeneration operations to surface waters or surface water drainage courses.
7. **Prohibition III.G (No discharge of wastewater from the Retention Ponds and Evaporation Ponds off-site).** Consistent with Order R5-2015-0071, this Order prohibits discharges of wastewater from the log yard retention pond, or evaporation ponds off-site, except to a suitable treatment plant or for reclamation purposes approved by the Executive Officer.

8. **Prohibition III.H (No discharge of debris recognized as originating from the Facility).** Effluent limitation guidelines (ELG's) were established at 40 C.F.R. part 429, subpart I for the Wet Storage Subcategory of the Timber Products Point Source Category, which applies to discharges from the storage of logs or roundwood on land during which water is sprayed or deposited intentionally on the logs (wet decking). The Discharger stacks logs on a paved log yard and keeps them wet by a sprinkler system to prevent checking and blue staining, and thus the requirements of 40 C.F.R. part 429, subpart I are applicable to the Facility. 40 C.F.R. sections 429.101 and 429.103 require that existing point sources subject to subpart I achieve effluent limitations representing the degree of effluent reduction attainable by the application of best practicable control technology currently available (BPT) and best available technology economically achievable (BAT), respectively. For wet storage operations, 40 C.F.R. sections 429.101 and 429.103 both require that there shall be no debris discharged. Debris is defined as woody material such as bark, twigs, branches, heartwood, or sapwood that will not pass through a 2.54 cm (1.0 in) diameter round opening and is present in the discharge from a wet storage facility. Consistent with 40 C.F.R. sections 429.101 and 429.103, this Order prohibits discharges of debris recognized as originated from the Facility to surface waters or surface water drainage courses.
9. **Prohibition III.I (No discharge of wastewater from barking, sawmill, and planing operations).** ELG's were established at 40 C.F.R. part 429, subpart A for the Barking Subcategory of the Timber Products Point Source Category, which applies to discharges from the barking of logs, and at subpart K for the Sawmills and Planing Mills Subcategory, which applies to discharges from timber products processing procedures that include bark removal, sawing, resawing, edging, trimming, planing, and machining. The Discharger operates barking, sawmill, and planing mill operations, and thus the requirements of 40 C.F.R. part 429, subparts A and K are applicable to the Facility. 40 C.F.R. section 429.21(a) require that existing point sources subject to subpart A achieve effluent limitations representing the degree of effluent reduction attainable by the application of BPT. For mechanical barking operations, 40 C.F.R. section 429.21(a) requires that there shall be no discharge of process wastewater pollutants into navigable waters. 40 C.F.R. sections 429.121 and 429.123 require that existing point sources subject to subpart K achieve effluent limitations representing the degree of effluent reduction attainable by the application of BPT and BAT, respectively. For sawmill and planing mill operations, 40 C.F.R. sections 429.121 and 429.123 requires that there shall be no discharge of process wastewater pollutants into navigable waters. Consistent with 40 C.F.R. sections 429.21(a), 429.121, and 429.123, this Order prohibits discharges of process wastewater from barking, sawmill, and planing operations.

B. Technology-Based Effluent Limitations

1. Scope and Authority

Section 301(b) of the CWA and implementing U.S. EPA permit regulations at 40 C.F.R. section 122.44 require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Best Professional Judgment (BPJ) in accordance with 40 C.F.R. section 125.3

The CWA requires that technology-based effluent limitations be established based on several levels of controls:

- a. Best practicable treatment control technology (BPT) represents the average of the best existing performance by well-operated facilities within an industrial category or subcategory. BPT standards apply to toxic, conventional, and non-conventional pollutants.
- b. Best available technology economically achievable (BAT) represents the best existing performance of treatment technologies that are economically achievable within an industrial point source category. BAT standards apply to toxic and non-conventional pollutants.
- c. Best conventional pollutant control technology (BCT) represents the control from existing industrial point sources of conventional pollutants including BOD, TSS, fecal coliform, pH, and oil and grease. The BCT standard is established after considering a two-part reasonableness test. The first test compares the relationship between the costs of attaining a reduction in effluent discharge and the resulting benefits. The second test examines the cost and level of reduction of pollutants from the discharge from publicly owned treatment works to the cost and level of reduction of such pollutants from a class or category of industrial sources. Effluent limitations must be reasonable under both tests.
- d. New source performance standards (NSPS) represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources.

The CWA requires U.S. EPA to develop effluent limitations, guidelines and standards (ELGs) representing application of BPT, BAT, BCT, and NSPS. Section 402(a)(1) of the CWA and 40 C.F.R. section 125.3 authorize the use of best professional judgment (BPJ) to derive technology-based effluent limitations on a case-by-case basis where ELGs are not available for certain industrial categories and/or pollutants of concern. Where BPJ is

used, the Central Valley Water Board must consider specific factors outlined in 40 C.F.R. section 125.3.

2. Applicable Technology-Based Effluent Limitations

The Discharger operates a “wet deck” log storage operation, a “barking” operation, and a “sawmills and planing mills” operation. Therefore, ELGs established in the Timber Products Processing Point Source Category (40 C.F.R. part 429), specifically, subpart A (Barking Subcategory), subpart I (Wet Storage Subcategory), and subpart K (Sawmills and Planing Mills Subcategory) are applicable.

Except as provided in 40 C.F.R. section 125.30 through 125.32, any existing point source subject to these subparts must achieve the following effluent limitations representing the degree of effluent reduction attainable by the application of BPT. The following effluent limitations apply to Discharge Point SW-005 and SW-006:

- a. Barking Operations. As discussed in section IV.A.9 of this Fact Sheet, ELG’s established at 40 C.F.R. part 429, subpart A for the Barking Subcategory of the Timber Products Point Source Category are applicable to the Facility. Consistent with 40 C.F.R. section 429.21(a), this Order establishes a prohibition of discharges of process wastewater from barking operations.
- b. Wet Storage Operations. As discussed in section IV.A.8 of this Fact Sheet, ELG’s established at 40 C.F.R. part 429, subpart I for the Wet Storage Subcategory of the Timber Products Point Source Category are applicable to the Facility. Consistent with 40 C.F.R. sections 429.101 and 429.103 and Order R5-2007-0145, this Order prohibits discharges of debris recognized as originated from the Facility to surface waters or surface water drainage courses.

40 C.F.R. sections 429.101 and 103 also require that the pH be within the range of 6.0 to 9.0. The ELG’s for the Wet Storage Subcategory at 40 C.F.R. sections 429.101 and 429.103 are not directly applicable to discharges of industrial storm water (i.e., subsequent to the first flush) from the log yard. However, if an instantaneous minimum and maximum pH of 6.0 and 9.0, respectively, must be achieved for discharges of process wastewater from the log yard area, the Central Valley Water Board finds that it should also be achievable for subsequent discharges of industrial storm water. Therefore, this Order includes instantaneous minimum and maximum effluent limitations for pH of 6.0 and 9.0 for discharges of industrial storm water based on BPJ.

- c. Sawmill and Planing Mill Operations. As discussed in section IV.A.5 of this Fact Sheet, ELG’s established at 40 C.F.R. part 429, subpart K for

the Sawmills and Planing Mills Subcategory of the Timber Products Point Source Category are applicable to the Facility. Consistent with 40 C.F.R. sections 429.121, and 429.123, this Order establishes a prohibition of discharges of process wastewater from sawmill and planing mill operations.

**Summary of Technology-based Effluent Limitations
Discharge Point SW-005 and SW-006**

Table F-4. Summary of Technology-based Effluent Limitations

Parameter	Units	Instantaneous Minimum	Instantaneous Maximum
Conventional Pollutants			
pH	standard units	6.0	9.0

C. Water Quality-Based Effluent Limitations (WQBEL's) and Storm Water Action Levels

1. Scope and Authority

CWA section 301(b) and 40 C.F.R. section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

Section 122.44(d)(1)(i) of 40 C.F.R. requires that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBEL's must be established using: (1) U.S. EPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBEL's when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

Finally, 40 C.F.R. section 122(d)(1)(vii) requires effluent limits to be developed consistent with any available waste load allocations developed and approved for the discharge.

As specified in 40 C.F.R. section 122.44(k), BMP's may be used in lieu of numeric effluent limitations when:

- a. Authorized under section 304(e) of the CWA for control of toxic pollutants and hazardous substances for ancillary industrial activities;
- b. Authorized under section 402(p) of the CWA for the control of storm water discharges;
- c. Numeric effluent limitations are infeasible; or
- d. The practices are reasonably necessary to achieve effluent limitations and standards or to carry out the purpose and intent of the CWA.

Section 402(p) of the CWA authorizes regulation of storm water discharges associated with industrial activities. Therefore, a combination of BMP's, storm water action levels, and receiving water limitations are utilized in this Order to regulate the discharge of pollutants in discharges of industrial storm water.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The Basin Plan designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. In addition, the Basin Plan implements State Water Board Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply.

The Basin Plan on page 2-1 states: "Protection and enhancement of existing and potential beneficial uses are primary goals of water quality planning..." and with respect to disposal of wastewaters states that "...disposal of wastewaters is [not] a prohibited use of waters of the State; it is merely a use which cannot be satisfied to the detriment of beneficial uses."

The federal CWA section 101(a)(2), states: "it is the national goal that wherever attainable, an interim goal of water quality which provides for the protection and propagation of fish, shellfish, and wildlife, and for recreation in and on the water be achieved by July 1, 1983." Federal Regulations, developed to implement the requirements of the CWA, create a rebuttable presumption that all waters be designated as fishable and swimmable. Federal Regulations, 40 CFR sections 131.2 and 131.10, require that all waters of the State regulated to protect the beneficial uses of public water

supply, protection and propagation of fish, shellfish and wildlife, recreation in and on the water, agricultural, industrial and other purposes including navigation. 40 C.F.R. section 131.3(e) defines existing beneficial uses as those uses actually attained after 28 November 1975, whether or not they are included in the water quality standards. Federal Regulation, 40 C.F.R. section 131.10 requires that uses be obtained by implementing effluent limitations, requires that all downstream uses be protected and states that in no case shall a state adopt waste transport or waste assimilation as a beneficial use for any waters of the United States.

- a. **Receiving Water and Beneficial Uses.** Canyon Creek flows into and out of Fruit Growers Pond, which is located immediately adjacent to and west of the Facility. Canyon Creek is tributary to Burney Creek. Refer to section III.C.1. above for a complete description of the receiving water beneficial uses.
- b. **Effluent and Ambient Background Data.** The evaluation of compliance with receiving water objectives, as described in section IV.C.3 of this Fact Sheet, was based on data from March 2016 and April 2019, which includes storm water effluent and ambient background data submitted in SMRs.
- c. **Assimilative Capacity/Mixing Zone.** Based on the available information, the worst-case dilution is assumed to be zero to provide protection for the receiving water beneficial uses. The impact of assuming zero dilution/assimilative capacity within the receiving water is that the discharge limitations are end-of-pipe limits with no allowance for dilution within the receiving water.
- d. **Conversion Factors.** The CTR contains aquatic life criteria for arsenic, cadmium, chromium III, chromium VI, copper, lead, nickel, silver, and zinc which are presented in dissolved concentrations. U.S. EPA recommends conversion factors to translate dissolved concentrations to total concentrations. The default U.S. EPA conversion factors contained in Appendix 3 of the SIP were used to convert the applicable dissolved criteria to total recoverable criteria.
- e. **Hardness-Dependent CTR Metals Criteria.** The CTR and the NTR contain water quality criteria for seven metals that vary as a function of hardness. The lower the hardness the lower the water quality criteria. The metals with hardness-dependent criteria include cadmium, copper, chromium III, lead, nickel, silver, and zinc.

Based on five samples collected between January 2017 and April 2019, the effluent hardness ranged from 48 mg/L to 86 mg/L, the upstream receiving water hardness ranged from 24 to 36 mg/L, and the downstream receiving water hardness ranged from 24 mg/L to 37 mg/L. The average

hardness for the upstream receiving water was approximately 29 mg/L and the average hardness for downstream receiving water was approximately 30 mg/L. Due to the short duration, periodic nature of storm events and corresponding intermittent storm water discharges from the Facility, the CTR acute criteria calculated using an average receiving water hardness of 29 mg/L were used for evaluating compliance with water quality objectives for the storm water discharge.

3. Determining the Need for Storm Water Action Levels

This Order regulates the discharge of storm water from industrial activity to surface water. The discharge is storm water; therefore, the SIP provisions for establishment of effluent limitations for CTR constituents are not applicable to the discharge. However, due to the complexity of the Facility and unique threats to water quality, the Central Valley Water Board has elected to regulate this Facility with an individual NPDES permit. In accordance with 40 C.F.R. section 122.44(d)(1)(i), the Central Valley Water Board has conducted a review of effluent (storm water) and upstream and downstream receiving water data collected during the term of Order R5-2014-0035 for comparison with applicable water quality objectives and/or criteria to determine if the discharge is causing exceedances of the applicable water quality objectives in the downstream receiving water. In addition, storm water discharge data has been compared to applicable storm water numeric action level values to assess whether the storm water discharge could potentially impair or contribute to impairing water quality or affect human health from ingestion of water or fish.

In accordance with 40 C.F.R. section 122.44(k), in lieu of WQBEL's, this Order includes storm water action levels for pollutants in the discharge that exceed applicable storm water numeric action level values or are causing exceedances of applicable water quality objectives in the downstream receiving water. The storm water action levels are not effluent limits and should not be interpreted as such; they are merely levels that the Central Valley Water Board has used to determine if storm water discharges from the Facility merit further monitoring to ensure that the Facility has been successful in implementing BMP's identified in the Storm Water Pollution Prevention Plan (SWPPP).

Downstream receiving water monitoring data, applicable water quality criteria and objectives, and storm water action levels have been provided in Attachment G.

Most constituents are not discussed in this Order, as the storm water discharge is well below the pollutant numeric action level values and/or the water quality objectives/criteria for these constituents. However, the following constituents are notable for discussion upon assessment of the data.

- a. **Chemical Oxygen Demand (COD).** COD is the amount of dissolved oxygen in water consumed by the chemical breakdown of organic and inorganic matter (i.e., COD is not a specific component in a discharge). A

high COD value indicates elevated quantities of pollutants in runoff, especially carbon. The storm water benchmark value in U.S. EPA's Multi-Sector General Permit for Stormwater Discharges Associated with Industrial Activity (MSGP) for General Sawmills and Planing Mills (SIC code 2421) for COD is 120 mg/L.

Effluent COD ranged from 28 mg/L to 228 mg/L in four samples collected between March 2016 and April 2019. Upstream and downstream receiving water monitoring data for COD is not available. Based on the levels of COD in the effluent and the nature of runoff from sawmill operations, a storm water action level of 120 mg/L for COD has been established in this Order based on the benchmark in U.S. EPA's MSGP. If exceeded, the Discharger is required to evaluate and update, if necessary, the Facility's BMP's in order to reduce the COD in the storm water discharge.

- b. **Iron.** U.S. EPA developed National Recommended Ambient Water Quality Criteria (NAWQC) for the protection of freshwater aquatic life for iron. The recommended 4-day average (chronic) criterion is 1,000 µg/L. In addition, the State Water Board Division of Drinking Water (DDW) has established Secondary MCL's to assist public drinking water systems in managing their drinking water for public welfare considerations, such as taste, color, and odor. The Secondary MCL for iron is 300 µg/L for protection of the MUN beneficial use. Title 22 requires compliance with Secondary MCL's on an annual average basis.

Total recoverable iron concentrations in the storm water effluent ranged from 243 µg/L to 1,170 µg/L, with a maximum of 1,170 µg/L, based on 4 samples collected from January 2017 through April 2019. Based on 4 samples collected concurrently in the upstream and downstream receiving water between January 2017 and April 2019, total recoverable iron concentrations in the upstream receiving water ranged from 173 µg/L to 286 µg/L, with a maximum annual average of 286 µg/L, and total recoverable iron concentrations in the downstream receiving water ranged from 189 µg/L to 313 µg/L, with a maximum annual average of 272 µg/L. Based on the available data, total recoverable iron concentrations in the downstream receiving water exceed the Secondary MCL. Additionally, there is evidence that the iron concentrations in the storm water effluent are contributing to exceedances of water quality objectives in the downstream receiving water. Therefore, this Order includes a storm water action level for iron of 1,000 µg/L based on the U.S. EPA NAWQC. If exceeded, the Discharger is required to evaluate and update, if necessary, the Facility's BMP's in order to reduce iron concentrations in the storm water discharge.

- c. **Manganese.** DDW has established Secondary MCL's to assist public drinking water systems in managing their drinking water for public welfare considerations, such as taste, color, and odor. The Secondary MCL for

manganese is 50 µg/L for protection of the MUN beneficial use. Title 22 requires compliance with Secondary MCL's on an annual average basis.

Total recoverable manganese concentrations in the storm water effluent ranged from 48.2 µg/L to 379 µg/L, with a maximum annual average of 188 µg/L, based on four samples collected from January 2017 through April 2019. Based on four samples collected concurrently in the upstream and downstream receiving water between January 2017 through April 2019, total recoverable manganese concentrations in the upstream receiving water ranged from 5.2 µg/L to 24.4 µg/L, with a maximum annual average of 17.4 µg/L, and total recoverable manganese concentrations in the downstream receiving water ranged from 8.9 µg/L to 36.5 µg/L, with a maximum annual average of 19 µg/L. Based on the available data, total recoverable manganese concentrations in the downstream receiving water did not exceed the Secondary MCL. Additionally, there is no evidence that the manganese concentrations in the storm water effluent are contributing to exceedances of water quality objectives in the downstream receiving water. Therefore, a storm water action level for manganese has not been established in this Order.

- d. **pH.** The Basin Plan includes a water quality objective for surface waters (except for Goose Lake) that the "...pH shall not be depressed below 6.5 nor raised above 8.5." The effluent pH ranged from 6.35 to 9.96 and the downstream receiving water pH ranged from 6.29 to 7.73 based on 20 samples collected between March 2016 and April 2019. Based on monitoring data indicating that the downstream receiving water is in compliance with the Basin Plan objectives, the Central Valley Water Board finds that the discharge does not exhibit reasonable potential to cause or contribute to an exceedance of the Basin Plan water quality objectives for pH. Therefore, this Order does not include WQBEL's or action levels for pH. However, as discussed in section IV.B.2 of this Fact Sheet, this Order includes technology-based minimum and maximum effluent limitations of 6.0 and 9.0, respectively, based on BPJ for discharges of industrial storm water.
- e. **Tannins and Lignins.** For inland surface waters, the Basin Plan states that "[w]ater shall be free of discoloration that causes nuisance or adversely effects beneficial uses." No numeric criteria or objectives for tannins and lignins have been developed. Tannins and lignins are generated from wood products and could cause discoloration or a pH shift of the effluent or receiving water. Some studies have indicated that elevated levels of tannins and lignins are harmful to aquatic life.

Effluent tannins and lignins ranged from 0.55mg/L to 18.8 mg/L in four samples collected between January 2017 and April 2019. Based on the levels of tannins and lignins in the effluent and the nature of runoff from sawmill operations, a storm water action level of 30 mg/L for tannins and

lignins has been retained from Order R5-2015-0071. If exceeded, the Discharger is required to evaluate and update, if necessary, the Facility's BMP's in order to reduce tannins and lignins in the storm water discharge.

- f. **Total Suspended Solids (TSS).** For inland surface waters, the Basin Plan states, "[w]aters shall not contain suspended material in concentrations that cause nuisance or adversely affect beneficial uses." The storm water annual average numeric action level value in the for General Sawmills and Planing Mills (SIC code 2421) for TSS is 100 mg/L and the instantaneous maximum is 400 mg/L.

Effluent TSS ranged from 2 mg/L to 415 mg/L in 32 samples collected between March 2016 and April 2019. Based on the levels of TSS in the effluent and the nature of runoff from sawmill operations, an annual average storm water action level of 100 mg/L and a maximum daily storm water action level of 400 mg/L for TSS has been established in this Order based on the numeric action level (NAL) values in Table 2 of the General Permit for Storm Water Associated with Industrial Activities Order 2014-0057-DWQ, NPDES Order No. CAS000001 (Industrial General Permit or IGP). If exceeded, the Discharger is required to evaluate and update, if necessary, the Facility's BMP's in order to reduce the TSS in the storm water discharge.

- g. **Zinc.** The CTR includes hardness-dependent criteria for the protection of freshwater aquatic life for zinc. These criteria for zinc are presented in dissolved concentrations, as 1-hour acute criteria and 4-day chronic criteria. U.S. EPA recommends conversion factors to translate dissolved concentrations to total concentrations. Default U.S. EPA translators were used for the effluent and receiving water. The Basin Plan also includes hardness-dependent criteria for zinc for the Sacramento River and its tributaries above the State Highway 32 bridge at Hamilton City, expressed in dissolved concentrations.

As described in section IV.C.2.e of this Fact Sheet, the applicable criteria for evaluation of compliance with the water quality objectives for hardness-dependent metals were calculated using an average receiving water hardness of 29 mg/L. Based on a design hardness of 29 mg/L, the applicable CTR acute and chronic criteria for zinc in the effluent are 41 µg/L, as dissolved concentrations. Additionally, using a design hardness of 29 mg/L, the applicable Basin Plan objective for zinc is 12 µg/L, as a dissolved concentration.

Based on 4 samples collected from February 2017 through April 2019, the MEC for dissolved zinc was 14.3 µg/L, the maximum observed dissolved zinc concentration in the upstream receiving water was 11.5 µg/L, and the maximum observed dissolved zinc concentration in the downstream receiving water was 9.4 µg/L. Based on evaluation of paired downstream

receiving water data, the discharge of storm water from the Facility is not causing or contributing to exceedances of water quality objectives in the receiving water. Therefore, a storm water action level for zinc has not been established in this Order.

4. **WQBEL Calculations**

This Order does not include WQBEL's for individual pollutants.

5. **Whole Effluent Toxicity (WET)**

For compliance with the Basin Plan's narrative toxicity objective, this Order requires the Discharger to conduct whole effluent toxicity testing for acute and chronic toxicity, as specified in the Monitoring and Reporting Program (Attachment E section V.). This Order also contains effluent limitations for acute and chronic toxicity and requires the Discharger to implement best management practices to investigate the causes of, and identify corrective actions to reduce or eliminate effluent toxicity.

- a. **Acute Aquatic Toxicity.** The Basin Plan contains a narrative toxicity objective that states, "All waters shall be maintained free of toxic substances in concentrations that produce detrimental physiological responses in human, plant, animal, or aquatic life." (Basin Plan at 3.1.20) The Basin Plan also states that, "...effluent limits based upon acute biotoxicity tests of effluents will be prescribed where appropriate...".

For priority pollutants, the SIP dictates the procedures for conducting the RPA. Acute toxicity is not a priority pollutant. Therefore, the Central Valley Water Board is not restricted to one particular RPA method. Acute whole effluent toxicity is not a priority pollutant. Therefore, due to the site-specific conditions of the discharge, the Central Valley Water Board has used professional judgment in determining the appropriate method for conducting the RPA. U.S. EPA's September 2010 NPDES Permit Writer's Manual, page 6-30, states, "State implementation procedures might allow, or even require, a permit writer to determine reasonable potential through a qualitative assessment process without using available facility-specific effluent monitoring data or when such data are not available...A permitting authority might also determine that WQBEL's are required for specific pollutants for all facilities that exhibit certain operational or discharge characteristics (e.g., WQBEL's for pathogens in all permits for POTW's discharging to contact recreational waters)." Acute toxicity effluent limits are required to ensure compliance with the Basin Plan's narrative toxicity objective.

U.S. EPA Region 9 provided guidance for the development of acute toxicity effluent limitations in the absence of numeric water quality objectives for toxicity in its document titled "Guidance for NPDES Permit Issuance", dated February 1994. In section B.2. "Toxicity Requirements" (pgs. 14-15) it states that, "In the absence of specific numeric water quality

objectives for acute and chronic toxicity, the narrative criterion 'no toxics in toxic amounts' applies. Achievement of the narrative criterion, as applied herein, means that ambient waters shall not demonstrate for acute toxicity: 1) less than 90% survival, 50% of the time, based on the monthly median, or 2) less than 70% survival, 10% of the time, based on any monthly median. For chronic toxicity, ambient waters shall not demonstrate a test result of greater than 1 TUc." Accordingly, effluent limitations for acute toxicity have been included in this Order as follows:

Acute Toxicity. Survival of aquatic organisms in 96-hour bioassays of undiluted waste shall be no less than:

70%, minimum for any one bioassay; and

90%, median for any three consecutive bioassays.

D. Final Effluent Limitation Considerations

1. Mass-based Effluent Limitations

40 C.F.R section 122.45(f)(1) requires effluent limitations be expressed in terms of mass, with some exceptions, and 40 C.F.R. section 122.45(f)(2) allows pollutants that are limited in terms of mass to additionally be limited in terms of other units of measurement. This Order includes effluent limitations expressed in terms of mass and concentration. In addition, pursuant to the exceptions to mass limitations provided in 40 C.F.R. section 122.45(f)(1), some effluent limitations are not expressed in terms of mass, such as pH and temperature, and when the applicable standards are expressed in terms of concentration (e.g., CTR criteria and MCL's) and mass limitations are not necessary to protect the beneficial uses of the receiving water.

2. Averaging Periods for Effluent Limitations

For non-continuous discharges, such as those from the Facility, 40 C.F.R. section 122.45(e) states:

- (1) Non-continuous discharges. Discharges which are not continuous, as defined in §122.2, shall be particularly described and limited, considering the following factors, as appropriate:
- (2) Frequency (for example, a batch discharge shall not occur more than once every 3 weeks);
- (3) Total mass (for example, not to exceed 100 kilograms of zinc and 200 kilograms of chromium per batch discharge);
- (4) Maximum rate of discharge of pollutants during the discharge (for example, not to exceed 2 kilograms of zinc per minute); and

- (5) Prohibition or limitation of specified pollutants by mass, concentration, or other appropriate measure (for example, shall not contain at any time more than 0.1 mg/l zinc or more than 250 grams (1/4 kilogram) of zinc in any discharge).

Thus, the Central Valley Water Board is not restricted to a particular averaging period for non-continuous discharges.

3. Satisfaction of Anti-Backsliding Requirements

The CWA specifies that a revised permit may not include effluent limitations that are less stringent than the previous permit unless a less stringent limitation is justified based on exceptions to the anti-backsliding provisions contained in CWA sections 402(o) or 303(d)(4), or, where applicable, 40 C.F.R. section 122.44(l).

The effluent limitations in this Order are at least as stringent as the effluent limitations in Order R5-2015-0071, with the exception of effluent limitations for settleable solids. The effluent limitations for settleable solids have not been retained from Order R5-2015-0071. This relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.

- a. CWA sections 402(o)(1) and 303(d)(4). CWA section 402(o)(1) prohibits the establishment of less stringent WQBEL's "except in compliance with section 303(d)(4)." CWA section 303(d)(4) has two parts: paragraph (A) which applies to nonattainment waters and paragraph (B) which applies to attainment waters.
- i. For waters where standards are not attained, CWA section 303(d)(4)(A) specifies that any effluent limit based on a TMDL or other WLA may be revised only if the cumulative effect of all such revised effluent limits based on such TMDLs or WLAs will assure the attainment of such water quality standards.
- ii. For attainment waters, CWA section 303(d)(4)(B) specifies that a limitation based on a water quality standard may be relaxed where the action is consistent with the antidegradation policy.

Canyon Creek is considered an attainment water for settleable solids because the receiving water is not listed as impaired on the 303(d) list for this constituent.¹ As discussed in section IV.D.4, below, removal of the effluent limits complies with federal and state antidegradation requirements. Thus, removal of effluent limitations for settleable solids from Order R5-2015-0071 meets the exception in CWA section 303(d)(4)(B).

- b. CWA section 402(o)(2). CWA section 402(o)(2) provides several exceptions to the anti-backsliding regulations. CWA section 402(o)(2)(B)(i) allows a renewed, reissued, or modified permit to contain a less-stringent effluent limitation for a pollutant if information is available that was not available at the time of permit issuance (other than revised regulations, guidance, or test methods) and that would have justified the application of a less-stringent effluent limitation at the time of permit issuance.

As described further in section IV.C.3 of this Fact Sheet, updated information that was not available at the time Order R5-2015-0071 was issued indicates that settleable solids in the storm water discharge do not exhibit reasonable potential to cause or contribute to an exceedance of water quality objectives in the receiving water. The updated information that supports the removal of effluent limitations for settleable solids includes the following:

- i. Settleable Solids. Effluent and receiving water monitoring data collected between March 2016 and April 2019. indicates that the discharge is not causing exceedances of the applicable water quality objectives for settleable solids in the downstream receiving water.

Thus, removal of the effluent limitations for settleable solids from Order R5 2015 0071 is in accordance with CWA section 402(o)(2)(B)(i), which allows for the removal of effluent limitations based on information that was not available at the time of permit issuance.

4. Antidegradation Policies

- a. **Surface Water.** This Order does not allow for an increase in flow or mass of pollutants to the receiving water. Therefore, a complete antidegradation analysis is not necessary. The Order requires compliance with applicable federal technology-based standards and with WQBEL's where the discharge could have the reasonable potential to cause or contribute to an exceedance of water quality standards. The permitted discharge is consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and the State Antidegradation Policy. Compliance with these requirements will result in the use of BPTC of the discharge. The impact on existing water quality will be insignificant.

This Order removes effluent limitations for settleable solids based on updated information, as described in sections IV.C.3 and IV.D.3 of this Fact Sheet. The removal of these WQBEL's will not result in a decrease in the level of treatment or control, or a reduction in water quality. Therefore, the Central Valley Water Board finds that the removal of the effluent limitations for settleable solids does not result in an allowed increase in pollutants or any additional degradation of the receiving water. Thus, the removal of effluent limitations is consistent with the antidegradation

provisions of 40 C.F.R. section 131.12 and the State Antidegradation Policy.

- b. **Groundwater.** The Discharger utilizes retention ponds, two evaporation ponds, and a substation pond to store process wastewater on site. Percolation from the ponds may result in an increase in the concentration of these constituents in groundwater. The State Anti-Degradation Policy generally prohibits the Central Valley Water Board from authorizing activities that will result in the degradation of high-quality waters unless it has been shown that:
 - i. The degradation will not result in water quality less than that prescribed in state and regional policies, including violation of one or more water quality objectives;
 - ii. The degradation will not unreasonably affect present and anticipated future beneficial uses;
 - iii. The discharger will employ Best Practicable Treatment or Control (BPTC) to minimize degradation; and
 - iv. The degradation is consistent with the maximum benefit to the people of the state.

Though the pond is unlined, the Central Valley Water Board considers the use of unlined ponds to store and treat process water to be an industry-standard practice that is an appropriate component of an effective suite of best management practices. This Order, specifically the Best Management Practices and Pollution Prevention measures required in section VI.D.3, will require the Discharger to implement BPTC. In addition, the Central Valley Water Board finds, based on existing information, that the limited groundwater degradation that may occur under this Order will not result in exceedances of any applicable groundwater water quality objectives or in any impacts to beneficial uses. Therefore, pollution or nuisance will not occur. Lastly, the limited degradation that may occur under this Order inheres to the maximum benefit of the people of the State because it will occur due to the operation of a biomass power generation facility that 1) is an important economic driver to the region, and 2) helps utilities meet State-mandated requirements for energy production from a renewable resource.

The Discharger will also be required to confirm that the discharge has not resulted in pollution or nuisance in a report, the Anti-Degradation Re-evaluation, which the Discharger will submit as part of its permit renewal application. Should the Anti-Degradation Re-evaluation reveal degradation inconsistent with the State Anti-Degradation Policy, the Discharger must propose additional treatment or control measure to further limit any impacts from the discharge.

5. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based effluent limitations and WQBEL's for individual pollutants. The technology-based effluent limitations consist of restrictions on pH. Restrictions on pH are discussed in IV.B.2 of this Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

WQBEL's have been derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBEL's were derived from the CTR, the CTR is the applicable standard pursuant to 40 C.F.R. section 131.38. The procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR implemented by the SIP, which was approved by U.S. EPA on 18 May 2000. Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

Summary of Final Effluent Limitations Discharge Points SW-005 and SW-006

Table F-5. Summary of Final Effluent Limitations

Parameter	Units	Effluent Limitations	Basis ¹
pH	standard units	Instantaneous Max 9.0 Instantaneous Min 6.0	BPJ
Acute Toxicity	% Survival	70 ² /90 ³	BP

Table F-14 Notes:

- BPJ – Based on Best Professional Judgment.
BP – Based on water quality objectives contained in the Basin Plan.
- Minimum for any one bioassay.
- Median for any three consecutive bioassays.

E. Interim Effluent Limitations – Not Applicable

F. Land Discharge Specifications – Not Applicable

G. Recycling Specifications – Not Applicable

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

1. CWA section 303(a-c), requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Central Valley Water Board adopted water quality criteria as water quality objectives in the Basin Plan. The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional Water Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains receiving surface water limitations based on the Basin Plan numerical and narrative water quality objectives for ammonia, bacteria, biostimulatory substances, color, chemical constituents, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, suspended sediment, settleable substances, suspended material, tastes and odors, temperature, toxicity, and turbidity.

B. Groundwater

1. Order R5-2015-0071 included site-specific groundwater limitations for electrical conductivity, iron, manganese and pH, and a narrative limit for taste, odor, chemical constituents, toxicity, and color, to protect the beneficial uses of underlying groundwater from unanticipated percolation from the Facility’s wastewater ponds (retention ponds, evaporation ponds, and substation pond). The removal of site-specific groundwater limitations will not unreasonably affect present and anticipated beneficial uses of the underlying groundwater nor result in water quality less than described in applicable policies. The removal of site-specific groundwater limitation is not expected to cause other impacts on water quality. The Central Valley Water Board finds that the removal of the site-specific groundwater limitations a) is to the maximum benefit to the people of the state; b) will not unreasonably affect present and anticipated beneficial uses of the underlying groundwater; and c) will not result in water quality less than that prescribed in policies, and is consistent with the antidegradation provisions of 40 C.F.R. section 131.12 and the State Antidegradation Policy.

VI. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with 40 C.F.R. section 122.41, and additional conditions applicable to specified

categories of permits in accordance with 40 C.F.R. section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Sections 122.41(a)(1) and (b) through (n) of 40 C.F.R. establish conditions that apply to all state issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) of 40 C.F.R. allows the state to omit or modify conditions to impose more stringent requirements. In accordance with 40 C.F.R. section 123.25, this Order omits federal conditions that address enforcement authority specified in 40 C.F.R. sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

B. Special Provisions

1. Reopener Provisions

- a. **Water Effects Ratio (WER) and Metal Translators.** A default WER of 1.0 has been used in this Order for calculating criteria for applicable inorganic constituents. In addition, default dissolved-to-total metal translators have been used to convert water quality objectives from dissolved to total recoverable when developing effluent limitations for <constituent(s)>. If the Discharger performs studies to determine site-specific WERs and/or site-specific dissolved-to-total metal translators, this Order may be reopened to modify the effluent limitations for the applicable inorganic constituents.
- b. **Drinking Water Policy.** On 26 July 2013, the Central Valley Water Board adopted Resolution R5-2013-0098, amending the Basin Plan and establishing a Drinking Water Policy. The State Water Board approved the Drinking Water Policy on 3 December 2013. This Order may be reopened to incorporate monitoring of drinking water constituents to implement the Drinking Water Policy.
- c. **Facility Water Balance Evaluation Work Plan and Study.** The Discharger shall prepare and submit a work plan to study and measure the volume of runoff from the log deck area, the fuel storage pile area, and the fly ash storage area to determine if the Facility currently has adequate pond storage for each runoff area to ensure wastewater is not discharged to surface water.
- d. **Central Valley Salinity Alternatives for Long-Term Sustainability (CV-SALTS).** On 31 May 2018, as part of the CV-SALTS initiative, the Central Valley Water Board approved Basin Plan Amendments to incorporate new strategies for addressing ongoing salt and nitrate accumulation in the Central Valley. On 16 October 2019 the State Water Board approved the Amendments. If approved by the Office of Administrative Law and U.S.

EPA, the Amendments would impose certain new requirements on salt and nitrate discharges. If the Amendments ultimately go into effect, this Order may be amended or modified to incorporate any newly-applicable requirements.

2. Special Studies and Additional Monitoring Requirements

- a. **Facility Water Balance Evaluation Work Plan and Study.** The Discharger shall prepare and submit a work plan for Central Valley Water Board staff approval to study the water balance for the log deck area, land application area, fire pond drainage area, retention pond, and evaporation ponds to determine if the Facility currently has adequate pond storage for each runoff area to ensure wastewater is not discharged to surface water.
- b. **Storm Water Action Levels and Best Management Practice (BMP) Improvement Evaluation.** As discussed in section IV.C.3 of this Fact Sheet, this Order establishes action levels for constituents of concern in discharges of industrial storm water. The storm water action levels are pollutant concentrations above which the Central Valley Water Board has determined the storm water discharge could adversely affect receiving water quality (and control measures must be evaluated). The storm water action levels are not effluent limitations. The levels are used to determine if storm water discharges from the Facility merit further monitoring to ensure that the Facility has been successful in implementing the SWPPP and/or if storm water pollution control measures must be reevaluated and improved upon.

In order to address storm water action level exceedances and/or receiving water limitation violations, the Discharger must evaluate BMP's and make necessary improvements to the Facility BMP's in order to reduce pollutants in the storm water discharge and to ensure protection of water quality.

- c. **Downgradient Monitoring Wells Evaluation.** Based on the groundwater monitoring results and a technical report from the previous permit term, the concentrations of certain constituents in downgradient wells MW-3 and MW-4 are statistically higher than background concentrations. The Discharger asserts downgradient concentrations of certain constituents are not elevated due to Facility discharges to groundwater, rather because the downgradient monitoring wells are in the area of a pond historically used for holding logs. Therefore, the Discharger shall evaluate whether new downgradient wells are necessary to correctly characterize downgradient groundwater quality in order to determine if degradation is occurring. The Discharger shall submit a Downgradient Monitoring Wells Evaluation Report and Monitoring Well Installation Workplan (if applicable) no later than 1 year after the effective date of this Order.

- d. **Antidegradation Re-evaluation.** The Discharger is required to submit an Antidegradation Re-evaluation, as specified in section VI.C.2.c, to confirm that the land discharge continues to be consistent with the State Anti-degradation Policy.

3. **Best Management Practices and Pollution Prevention**

- a. **Salinity Evaluation and Minimization Plan.** An Evaluation and Minimization Plan for salinity is required in this Order to ensure adequate measures are developed and implemented by the Discharger to reduce the discharge of salinity to Canyon Creek. The requirements of this plan will be included in the SWPPP.
- b. **Storm Water Pollution Prevention Plan (SWPPP).** This Order requires the Discharger to implement BMP's, including treatment controls where necessary, in order to support attainment of water quality standards. The use of BMP's to control or abate the discharge of pollutants is allowed by 40 C.F.R. section 122.44(k)(3) because effluent limitations are infeasible and BMP's are reasonably necessary to achieve effluent limitations and are standards or to carry out the purposes and intent of the CWA. (40 C.F.R. 122.44(k)(4).)

This Order requires the Discharger to continue to implement a site-specific SWPPP for the Facility. The SWPPP is necessary to identify potential sources of pollutants that may come in contact with storm water and to control or abate the discharge of pollutants to surface water or groundwater.

In order to maintain an accurate and useful SWPPP, the SWPPP must be revised when whenever there is a change in construction, site operation, or maintenance, which may affect the discharge of significant quantities of pollutants to surface water or groundwater. The SWPPP must also be amended if there are violations of this Order, or the Discharger has not achieved the general objectives of controlling pollutants in the storm water discharges.

- c. **Facility-Specific BMP – First Flush Collection.** This Order specifies a BMP that defines a quantity of storm water that must be collected, after cessation of log sprinkling, and discharged to the Facility log deck retention pond prior to subsequent storm water being allowed to be discharged off-site to surface water. During the previous permit term, the Discharger conducted a log deck flushing study to identify the minimum amount of rainfall needed to “flush” the log deck area of pollutants, however this study was inconclusive. Therefore, this Order maintains the same first flush volume as the previous order but requires the Discharger to conduct Facility Water Balance Evaluation Study to determine if there is adequate first flush storage. The “first flush” collection may occur more

than once in a wet season if the Discharger intermittently sprinkles logs with pond water during the wet season.

4. Construction, Operation, and Maintenance Specifications

- a. **Facility Retention Pond, Log Yard Retention Pond, Fire Pond, Evaporation Ponds, and Substation Pond Operating Requirements.** The operation and maintenance specifications for the Facility retention ponds, fire pond, evaporation ponds, and substation pond are necessary to protect the beneficial uses of the groundwater. Specifications included in Order R5-2015-0071 are retained in this Order. In addition, reporting requirements related to use of the ponds are required to monitor their use and the potential impact on groundwater.

5. Special Provisions for Publicly-Owned Treatment Works (POTWs) – Not Applicable

6. Other Special Provisions

- a. Sludge, Wood Waste, and/or Ash Management Disposal. Sludge disposal provisions are necessary to ensure proper disposal of collected screening, sludges, wood ash, wood waste, and other solids removed from liquid wastes, ponds, or other sources in a manner that is consistent with Title 27, California Code of Regulations (CCR), Division 2, Subdivision 1, Section 20005, et seq, and approved by the Executive Officer.

7. Compliance Schedules – Not Applicable

VII. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

CWA section 308 and 40 C.F.R. sections 122.41(h), (j)-(l), 122.44(i), and 122.48 require that all NPDES permits specify monitoring and reporting requirements. Water Code sections 13267 and 13383 also authorize the Central Valley Water Board to establish monitoring, inspection, entry, reporting, and recordkeeping requirements. The Monitoring and Reporting Program (MRP), Attachment E of this Order establishes monitoring, reporting, and recordkeeping requirements that implement federal and state requirements. The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring – Not Applicable

B. Effluent Monitoring

1. Pursuant to the requirements of 40 C.F.R. section 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. Effluent monitoring is necessary to assess compliance with effluent limitations, assess the effectiveness of the treatment process, and to assess the impacts of the discharge on the receiving stream and groundwater.

2. Effluent monitoring frequencies and sample types for oil and grease (semi-annually), flow (daily), (pH (weekly), COD (monthly), electrical conductivity (weekly), hardness (monthly), settleable solids (weekly), total suspended solids (weekly), tannins and lignins (monthly), and turbidity (weekly) have been retained from Order R5-2015-0071 to determine compliance with effluent limitations, where applicable, and characterize the discharge for these parameters.
3. This Order requires biweekly monitoring for total and dissolved iron and manganese. This Order increases the monitoring frequency from monthly to biweekly to more accurately characterize the discharge. Biweekly aluminum was added to effluent monitoring. This constituent was added in order to collect more data and to more accurately characterize the discharge. Only one data point was collected in the previous permit term and exceeded the secondary MCL for aluminum.
4. In accordance with Section 1.3 of the SIP, periodic monitoring for priority pollutants for which criteria or objectives apply and for which no effluent limitations have been established is required. This Order requires monitoring during the first discharge event that occurs during the permit term in order to collect data to conduct an RPA for the next permit renewal. See section IX.C of the MRP for more detailed requirements related to performing priority pollutant monitoring.
5. Water Code section 13176, subdivision (a), states: "The analysis of any material required by [Water Code sections 13000-16104] shall be performed by a laboratory that has accreditation or certification pursuant to Article 3 (commencing with section 100825) of chapter 4 of part 1 of division 101 of the Health and Safety Code." DDW accredits laboratories through its Environmental Laboratory Accreditation Program (ELAP).

Section 13176 cannot be interpreted in a manner that would violate federal holding time requirements that apply to NPDES permits pursuant to the CWA (Wat. Code sections 13370, subd. (c), 13372, 13377). Section 13176 is inapplicable to NPDES permits to the extent it is inconsistent with CWA requirements (Wat. Code sections 13372, subd. (a)). The holding time requirements are 15 minutes for chlorine residual, dissolved oxygen, and pH, and immediate analysis is required for temperature (40 C.F.R. section 136.3(e), Table II). Due to the location of the Facility, it is both legally and factually impossible for the Discharger to comply with section 13176 for constituents with short holding times.

C. Whole Effluent Toxicity Testing Requirements

1. **Acute Toxicity.** Consistent with Order R5-2015-0071, semi-annual 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity.

2. **Chronic Toxicity.** Consistent with Order R5-2015-0071, once per permit term chronic whole effluent toxicity testing is required in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

D. Receiving Water Monitoring

1. Surface Water

- a. Receiving water monitoring is necessary to assess compliance with receiving water limitations and to assess the impacts of the discharge on the receiving stream.
- b. Receiving water monitoring requirements at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004 have been retained for dissolved oxygen (weekly), flow (weekly), pH (weekly), electrical conductivity (weekly), hardness (monthly), temperature (weekly), and turbidity (weekly).
- c. Order R5-2015-0071 required monthly receiving water monitoring for total and dissolved zinc and manganese at Monitoring Locations RSW-001, RSW-002, RSW-003, and RSW-004. This Order increases the monitoring frequency for iron from monthly to biweekly. The Central Valley Water Board finds that this frequency is necessary to assess the impact of the discharge on the receiving water for this parameter.
- d. In accordance with Section 1.3 of the SIP, periodic monitoring for priority pollutants for which criteria or objectives apply and for which no effluent limitations have been established. This Order requires monitoring for priority pollutants and other pollutants of concern during the first discharge event that occurs during the permit term in the upstream receiving water, concurrent with effluent monitoring, in order to collect data to conduct an RPA for the next permit renewal. See section IX.C of the Monitoring and Reporting Program (Attachment E) for more detailed requirements related to performing priority pollutant monitoring.

2. Groundwater

- a. Water Code section 13267 states, in part, "(a) A Regional Water Board, in establishing waste discharge requirements may investigate the quality of any waters of the state within its region" and "(b)(1) In conducting an investigation, the Regional Water Board may require that any person who discharges waste that could affect the quality of waters within its region shall furnish, under penalty of perjury, technical or monitoring program reports which the Regional Water Board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports." The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In

requiring those reports, a Regional Water Board shall provide the person with a written explanation with regard to the need for the reports and shall identify the evidence that supports requiring that person to provide the reports. The Monitoring and Reporting Program is issued pursuant to Water Code section 13267. The groundwater monitoring and reporting program required by this Order and the Monitoring and Reporting Program are necessary to assure compliance with these waste discharge requirements. The Discharger is responsible for the discharges of waste at the facility subject to this Order.

- b. Monitoring of the groundwater must be conducted to confirm that any groundwater degradation resulting from the discharge is in compliance with the groundwater limitations contained in this Order, and ensure protection of beneficial uses and compliance with Central Valley Water Board and State Water Board plans and policies, including the State Anti-Degradation Policy. This Order requires a regular schedule of groundwater monitoring in the attached Monitoring and Reporting Program.

E. Other Monitoring Requirements

1. Precipitation Monitoring

Precipitation monitoring is necessary to assess the amount of rainfall that falls on the log yard area.

2. Ash and Cooling Tower Solids Monitoring

The annual ash and cooling tower solids report is necessary to determine the quantity of ash and cooling tower solids generated at the Facility and to ensure the proper handling of such material.

3. Pond Monitoring

Pond monitoring requirements for freeboard is necessary to assess compliance with pond operating requirements and to ensure pond integrity. Pond monitoring for arsenic, pH, electrical conductivity, COD, chloride, copper, sulfate, total dissolved solids, iron, manganese, and zinc are necessary to assess the impacts of the discharge on groundwater.

VIII. PUBLIC PARTICIPATION

The Central Valley Water Board has considered the issuance of WDR's that will serve as an NPDES permit for Sierra Pacific Industries Burney. As a step in the WDR adoption process, the Central Valley Water Board staff has developed tentative WDR's and has encouraged public participation in the WDR adoption process.

A. Notification of Interested Persons

The Central Valley Water Board notified the Discharger and interested agencies and persons of its intent to prescribe WDR's for the discharge and provided an opportunity to submit written comments and recommendations. Notification was provided through physical posting, mailing, and internet posting.

The public had access to the agenda and any changes in dates and locations through the [Central Valley Water Board's website](http://www.waterboards.ca.gov/centralvalley/board_info/meetings/) (http://www.waterboards.ca.gov/centralvalley/board_info/meetings/)

B. Written Comments

Interested persons were invited to submit written comments concerning tentative WDR's as provided through the notification process. Comments were due either in person or by mail to the Executive Office at the Central Valley Water Board at the address on the cover page of this Order.

To be fully responded to by staff and considered by the Central Valley Water Board, the written comments were due at the Central Valley Water Board office by 5:00 p.m. on **<Date>**.

C. Public Hearing

The Central Valley Water Board held a public hearing on the tentative WDR's during its regular Board meeting on the following date and time and at the following location:

Date: 16-17 April 2020

Time: 8:30 a.m.

Location: Regional Water Quality Control Board, Central Valley Region
First Floor, Board of Supervisors

11020 Sun Center Dr., Suite #200
Rancho Cordova, CA 95670

Interested persons were invited to attend. At the public hearing, the Central Valley Water Board heard testimony pertinent to the discharge, WDR's, and permit. For accuracy of the record, important testimony was requested in writing.

D. Reconsideration of Waste Discharge Requirements

Any person aggrieved by this action of the Central Valley Water Board may petition the State Water board to review the action in accordance with Water Code section 13320 and California Code of Regulations, title 23, sections 2050 and following. The State Water Board must receive the petition by 5:00 p.m., within 30 calendar days of the date of adoption of this Order at the following address, except that if the thirtieth day following the date of this Order falls on a Saturday, Sunday, or state holiday, the

petition must be received by the State Water Board by 5:00 p.m. on the next business day:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

Or by email at waterqualitypetitions@waterboards.ca.gov

[Instructions on how to file a petition for review](http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instructions.shtml)

(http://www.waterboards.ca.gov/public_notices/petitions/water_quality/wqpetition_instructions.shtml) are available on the Internet.

E. Information and Copying

The Report of Waste Discharge, other supporting documents, and comments received are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Central Valley Water Board by calling (916) 464-3291.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDR's and NPDES permit should contact the Central Valley Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Stacey Alexander at (530) 224-3219.

ATTACHMENT G – SUMMARY OF COMPLIANCE WITH RECEIVING WATER OBJECTIVES

Constituent	Units	B	C	CMC	CCC	Water & Org	Org. Only	Basin Plan	SWAL	RW Obj. Met?
Aluminum, Total Recoverable	ug/L	NR	750	750	--	--	--	--	--	Inconclusive
Chemical Oxygen Demand	mg/L	NR	120	--	--	--	--	--	120	Inconclusive
Copper, Total Recoverable	µg/L	.8	3.1	3.1	4.3	1,300	--	5.9	--	Yes
Electrical Conductivity @ 25°C	µmhos/cm	128.44	900	--	--	--	--	--	--	Yes
Iron, Total Recoverable	µg/L	313	300	--	1,000	--	--	--	1000	No
Manganese, Total Recoverable	µg/L	36.5	1,000	--	1000	--	--	--	1000	Yes
Tannins and Lignins	mg/L	NA	500	--	--	--	--	--	30	Inconclusive
Zinc, Total Recoverable	µg/L	11.5	12	41	41	--	--	12	5,000	Yes

General Note: All inorganic concentrations are given as a total recoverable.

Abbreviations used in this table:

B = Maximum Receiving Water Concentration or lowest detection level, if non-detect
C = Criterion Used for Compliance with Water Quality Objective
CMC = Criterion Maximum Concentration (CTR or NTR)
CCC = Criterion Continuous Concentration (CTR or NTR)
Water & Org = Human Health Criterion for Consumption of Water & Organisms (CTR or NTR)
Org Only = Human Health Criterion for Consumption of Organisms Only (CTR or NTR)

SIERRA PACIFIC INDUSTRIES
BURNEY DIVISION

Basin Plan = Numeric Site-Specific Basin Plan Water Quality Objective
MCL = Drinking Water Standards Maximum Contaminant Level
NA = Not Available
ND = Non-detect

ORDER R5-2020-XXXX
NPDES NO. CA0003981